

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name Bear Creek MHP

PWS ID# 41 00050

Month/Year Jun 1/2025 Entry Point 51

Required Minimum Residual .4 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	10:45	Wells 1-2-3	.5	
2	9:12a	Combined	.5	
3	1:12p		.5	
4	7:49a		.5	
5	7:53a		.5	
6	7:15a		.5	
7	7:10a		.55	
8	7:41a		.55	
9	10:17a		.55	
10	10:11a		.55	
11	7:36a		.55	
12	8:49a		.55	
13	8:12a		.55	
14	7:41a		.55	
15	7:42p		.55	
16	10:37a		.55	
17	9:50a		.55	
18	10:32a		.55	
19	10:07a		.55	
20	11:33a		.5	
21	11:44a		.5	
22	11:14a		.5	
23	10:03a		.5	
24	9:45a		.55	
25	10:34a		.55	
26	11:12a		.5	
27	10:05a		.5	
28	10:29a		.55	
29	11:47a		.55	
30	10:25a		.55	
31				

Was the chlorine residual ever less than the required minimum residual of .4 mg/L? ☐ Yes ☒ No

If yes, what was the longest time period until the required level was restored? _____ hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer

If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? ☐ Yes ☐ No

Attach those results and submit them with this form.

GWS Serving More Than 3,300

Did continuous monitoring equipment fail at any time this reporting month? ☐ Yes ☐ No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? ☐ Yes ☐ No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed: / /

Date it was returned to service: / /

Printed Name: Mike Skinner

Title: Water System Operator

Operator Certification #:

Signature: Mike Skinner

Phone #: (541) 414-2232

OR

Date: 7/1/2025

Small Groundwater System ☒