

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name Bay City Water System

PWS ID# 4 1 00079

Month/Year 05/2022

Entry Point: Wells

Required Minimum Residual 0.20 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	10:55	1	.32	
2	8:30	1	.30	
3	7:55	1	.29	
4	7:55	1	.32	
5	7:55	2	.37	
6	9:20	2	.29	
7	8:45	1	.31	
8	9:40	2	.30	
9	7:45	2	.36	
10	8:00	1	.33	
11	8:20	1	.35	
12	8:00	2	.36	
13	8:55	1	.34	
14	9:00	1	.36	
15	9:30	2	.36	
16	8:10	2	.31	
17	7:50	2	.28	
18	7:55	1	.29	
19	8:40	2	.30	
20	9:22	1	.34	
21	9:45	2	.28	
22	10:30	1	.34	
23	8:30	1	.33	
24	7:45	1	.33	
25	8:00	1	.33	
26	8:15	1	.33	
27	9:10	1	.33	
28	7:15	2	.31	
29	9:10	2	.29	
30	9:20	2	.31	
31	8:30	2	.29	

Was the chlorine residual ever less than the required minimum residual of 0.20 mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to 0.20 mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach those results and submit them with this form.</i></p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach grab sample results and submit them with this form.</i></p>	<p>Date continuous monitoring equipment failed: / /</p> <p>Date it was returned to service: / /</p>
--	---	---

Printed Name: brian Bettis Signature:  Date: 06 / 01 / 2022	Title: Bay City Water Technician Phone #: (503) 377-4121	Operator Certification #: T-09089 OR Small Groundwater System <input type="checkbox"/>
--	---	--