

**State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems**

System Name Bay City Water System

PWS ID# 4 1 00079

Month/Year 07/2022 Entry Point: Wells

Required Minimum Residual 0.20 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	9:05	2	.31	
2	8:10	1	.36	
3	8:50	1	.30	
4	10:25	1+2	.35	
5	8:55	1	.31	
6	8:15	2	.30	
7	8:50	1	.29	
8	9:30	2	.39	
9	8:05	2	.34	
10	8:45	2	.34	
11	8:05	1	.29	
12	8:30	1	.25	
13	8:20	2	.24	
14	8:20	1	.27	
15	8:30	1+2	.30	
16	8:35	1	.30	
17	8:35	2	.30	
18	7:35	2	.35	
19	8:00	1	.30	
20	8:30	1	.27	
21	8:05	1+2	.31	
22	8:35	1	.29	
23	9:45	2	.34	
24	8:05	2	.33	
25	7:50	2	.34	
26	8:05	2	.30	
27	8:30	2	.31	
28	8:00	-	.32	
29	7:45	2	.32	
30	11:00	1+2	.29	
31	10:50	1+2	.30	

Was the chlorine residual ever less than the required minimum residual of 0.20 mg/L?  Yes  No  
 If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p><b>GWS Serving 3,300 or Fewer</b></p> <p>If yes, did you monitor every four hours until the residual returned to 0.20 mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach those results and submit them with this form.</i></p>	<p><b>GWS Serving More Than 3,300</b></p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach grab sample results and submit them with this form.</i></p>	<p>Date continuous monitoring equipment failed: / /</p> <p>Date it was returned to service: / /</p>
--	---	---

Printed Name: brian Bettis

Title: Bay City Water Technician

Operator Certification #: T-09089

Signature: 

Phone #: (503) 377-4121

OR

Date: 08 / 03 / 2022

Small Groundwater System