

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name	Bay City Water System	PWS ID#	4 1 00079
Month/Year	12/2022	Entry Point:	Wells
		Required Minimum Residual	0.20 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	8:10	2	.28	
2	8:20	2	.32	
3	9:50	2	.30	
4	10:20	1	.29	
5	7:50	1	.29	
6	7:40	-	.35	
7	7:15	2	.38	
8	8:05	1	.30	
9	8:25	2	.28	
10	10:30	1	.33	
11	9:45	1	.30	
12	8:00	1	.30	
13	7:55	1	.34	
14	7:55	1	.35	
15	8:05	1	.34	
16	8:35	1	.34	
17	11:00	2	.34	
18	10:00	1	.33	
19	8:15	1+2	.29	
20	8:30	2	.27	
21	10:55	2	.30	
22	9:40	2	.32	
23	7:55	2	.35	
24	9:55	2	.35	
25	11:30	2	.36	
26	8:35	-	.31	
27	9:15	2	.38	
28	8:30	1	.25	
29	8:30	1	.25	
30	8:30	1	.35	
31	8:30	2	.26	

Was the chlorine residual ever less than the required minimum residual of 0.20 mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to 0.20 mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach those results and submit them with this form.</i></p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach grab sample results and submit them with this form.</i></p>	<p>Date continuous monitoring equipment failed:</p> <p align="center">/ /</p> <p>Date it was returned to service:</p> <p align="center">/ /</p>
--	---	---

Printed Name: brian Bettis	Title: Bay City Water Technician	Operator Certification #: T-09089
Signature: <u>B. Bettis</u>	Phone #: (503) 377-4121	OR
Date: 01 / 06 / 2023		Small Groundwater System <input type="checkbox"/>