

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name Bay City Water System

PWS ID# 4 1 00079

Month/Year 04/2023 Entry Point: Wells

Required Minimum Residual 0.20 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	11:00	2	.27	
2	10:50	1	.33	
3	7:45	1	.34	
4	7:45	2	.31	
5	8:10	2	.33	
6	8:30	-	.31	
7	8:30	1	.36	
8	11:10	2	.34	
9	11:50	2	.35	
10	8:05	2	.31	
11	8:20	1	.31	
12	7:55	1	.32	
13	8:30	2	.32	
14	9:00	2	.34	
15	10:55	2	.35	
16	9:55	-	.29	
17	8:10	1	.32	
18	7:55	2	.28	
19	9:35	2	.32	
20	8:05	1	.35	
21	8:00	1	.33	
22	7:25	1	.36	
23	10:25	2	.35	
24	8:50	1	.36	
25	8:45	1	.35	
26	8:20	2	.36	
27	8:10	2	.37	
28	10:45	2	.37	
29	8:10	1	.32	
30	8:35	1	.33	
31				

Was the chlorine residual ever less than the required minimum residual of 0.20 mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to 0.20 mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach those results and submit them with this form.</i></p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach grab sample results and submit them with this form.</i></p>	<p>Date continuous monitoring equipment failed: / /</p> <p>Date it was returned to service: / /</p>
--	--	---

Printed Name: brian Bettis	Title: Bay City Water Technician	Operator Certification #: T-09089
Signature: 	Phone #: (503) 377-4121	OR
Date: 05 / 01 / 2023		Small Groundwater System <input type="checkbox"/>