

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name Bay City Water System

PWS ID# 4 1 00079


Month/Year 07/2023 Entry Point: Wells

Required Minimum Residual 0.20 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	7:50	1	.34	
2	9:00	1	.33	
3	8:55	2	.37	
4	9:50	2	.35	
5	8:30	2	.32	
6	8:15	1	.31	
7	8:25	1+2	.35	
8	8:00	1	.31	
9	8:55	2	.34	
10	7:50	1+2	.37	
11	7:45	1	.31	
12	9:00	2	.34	
13	9:20	2	.33	
14	8:00	2	.33	
15	7:50	2	.34	
16	10:00	-	.35	
17	8:40	1+2	.32	
18	8:20	-	.31	
19	8:00	2	.30	
20	8:10	2	.29	
21	8:00	1	.29	
22	8:45	2	.29	
23	9:35	1	.28	
24	9:20	1	.31	
25	8:30	2	.30	
26	9:10	1+2	.37	
27	8:15	1+2	.37	
28	8:10	1+2	.39	
29	9:55	1	.35	
30	9:50	1	.34	
31	8:15	2	.39	

Was the chlorine residual ever less than the required minimum residual of 0.20 mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to 0.20 mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach those results and submit them with this form.</i></p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach grab sample results and submit them with this form.</i></p>	<p>Date continuous monitoring equipment failed:</p> <p align="center">/ /</p> <p>Date it was returned to service:</p> <p align="center">/ /</p>
--	---	---

Printed Name: brian Bettis	Title: Bay City Water Technician	Operator Certification #: T-09089
Signature: 	Phone #: (503) 377-4121	OR
Date: 08 / 04 / 2023		Small Groundwater System <input type="checkbox"/>