

**State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems**

System Name	Bay City Water System	PWS ID#	41 00079
Month/Year	09/2023	Entry Point:	Wells
		Required Minimum Residual	0.20 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	8:55	1	.29	
2	11:00	1	.31	
3	11:40	1	.30	
4	9:25	1	.27	
5	9:55	1+2	.31	
6	8:05	1+2	.26	
7	7:05	1+2	.30	
8	8:16	1+2	.34	
9	11:30	1	.35	
10	10:30	1	.33	
11	8:45	1	.30	
12	6:55	1	.32	
13	7:00	2	.32	
14	7:10	2	.31	
15	8:05	1	.32	
16	8:45	1+2	.29	
17	9:15	1	.32	
18	9:10	1+2	.30	
19	6:50	1	.32	
20	7:40	2	.32	
21	7:30	1	.32	
22	8:25	2	.30	
23	9:20	2	.32	
24	9:30	1	.28	
25	7:40	2	.32	
26	7:45	1	.31	
27	7:05	1	.31	
28	6:55	1	.32	
29	10:00	1	.32	
30	6:10	1	.32	
31				

Was the chlorine residual ever less than the required minimum residual of 0.20 mg/L?  Yes  No  
 If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p><b>GWS Serving 3,300 or Fewer</b></p> <p>If yes, did you monitor every four hours until the residual returned to 0.20 mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach those results and submit them with this form.</i></p>	<p><b>GWS Serving More Than 3,300</b></p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach grab sample results and submit them with this form.</i></p>	<p>Date continuous monitoring equipment failed:</p> <p align="center">/ /</p> <p>Date it was returned to service:</p> <p align="center">/ /</p>
--	---	---

Printed Name: brian Bettis	Title: Bay City Water Technician	Operator Certification #: T-09089
Signature:	Phone #: (503) 377-4121	OR
Date: 10 / 5 / 2023		Small Groundwater System <input type="checkbox"/>