

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name Bay City Water System

PWS ID# 4 1 00079

Month/Year 12/2023

Entry Point: Wells

Required Minimum Residual 0.20 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	8:00	-	.31	
2	9:40	2	.31	
3	9:20	2	.31	
4	8:15	1	.45	
5	8:35	2	.34	
6	7:10	2	.31	
7	7:05	1	.30	
8	7:35	1	.34	
9	10:25	1	.31	
10	11:00	1	.32	
11	7:05	1	.33	
12	8:00	-	.28	
13	8:20	1	.36	
14	7:30	1	.33	
15	6:25	2	.34	
16	11:40	2	.29	
17	10:40	2	.27	
18	9:05	1	.34	
19	8:45	1	.36	
20	9:15	2	.29	
21	8:20	1	.30	
22	8:30	2	.32	
23	11:35	2	.31	
24	11:50	2	.30	
25	8:40	-	.35	
26	10:00	2	.33	
27	8:15	2	.34	
28	8:00	2	.34	
29	9:15	2	.31	
30	8:30	2	.35	
31	8:30	1	.31	

Was the chlorine residual ever less than the required minimum residual of 0.20 mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to 0.20 mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach those results and submit them with this form.</i></p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach grab sample results and submit them with this form.</i></p>	<p>Date continuous monitoring equipment failed: _____ / _____ / _____</p> <p>Date it was returned to service: _____ / _____ / _____</p>
--	---	---

Printed Name: brian Bettis

Title: Bay City Water Technician

Operator Certification #: T-09089

Signature: 

Phone #: (503) 377-4121

OR

Date: 01 / 05 / 2024

Small Groundwater System