

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name Bay City Water System

PWS ID# 41 00079

Month/Year 03/2024


Entry Point: Wells

Required Minimum Residual 0.20 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	8:45	1	.31	
2	12:10	1	.32	
3	10:45	2	.34	
4	8:15	2	.30	
5	8:55	2	.33	
6	8:50	1	.31	
7	8:10	2	.33	
8	8:20	2	.33	
9	8:40	2	.35	
10	8:40	1	.33	
11	9:35	2	.35	
12	8:05	2	.39	
13	7:55	2	.30	
14	7:50	-	.30	
15	8:20	1	.33	
16	8:20	1	.33	
17	8:15	1	.33	
18	8:05	1	.38	
19	8:15	1	.32	
20	7:55	1	.28	
21	8:05	1	.34	
22	8:00	1	.25	
23	7:50	1	.29	
24	7:55	1	.31	
25	8:05	2	.36	
26	8:20	2	.34	
27	8:00	2	.36	
28	8:15	1	.32	
29	9:45	1	.37	
30	10:15	2	.38	
31	10:00	1	.31	

Was the chlorine residual ever less than the required minimum residual of 0.20 mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to 0.20 mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach those results and submit them with this form.</i></p>	<p align="center">GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach grab sample results and submit them with this form.</i></p> <p>Date continuous monitoring equipment failed: / /</p> <p>Date it was returned to service: / /</p>
--	--

Printed Name: brian Bettis	Title: Bay City Water Technician	Operator Certification #: T-09089
Signature: 	Phone #: (503) 377-4121	OR
Date: 04 / 05 / 2024		Small Groundwater System <input type="checkbox"/>