

**State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems**

System Name Bay City Water System

PWS ID# 4 1 00079

Month/Year 08/2025

Entry Point: Wells

Required Minimum Residual 0.20 mg/L

| Date | Time  | Source(s) in use | Lowest free chlorine residual at entry point to distribution system (mg/L) | Notes |
|------|-------|------------------|----------------------------------------------------------------------------|-------|
| 1    | 7:20  | 1                | .33                                                                        |       |
| 2    | 6:45  | 1                | .41                                                                        |       |
| 3    | 6:45  | 1                | .37                                                                        |       |
| 4    | 8:20  | 2                | .39                                                                        |       |
| 5    | 8:25  | 1                | .41                                                                        |       |
| 6    | 8:10  | 1                | .41                                                                        |       |
| 7    | 8:40  | 1+2              | .36                                                                        |       |
| 8    | 7:10  | 1                | .38                                                                        |       |
| 9    | 7:50  | 1                | .36                                                                        |       |
| 10   | 8:00  | 1                | .35                                                                        |       |
| 11   | 8:45  | 2                | .25                                                                        |       |
| 12   | 8:30  | 2                | .40                                                                        |       |
| 13   | 8:15  | 1+2              | .42                                                                        |       |
| 14   | 8:30  | 2                | .38                                                                        |       |
| 15   | 8:20  | -                | .25                                                                        |       |
| 16   | 1:00  | 1                | .45                                                                        |       |
| 17   | 11:30 | 2                | .36                                                                        |       |
| 18   | 8:45  | 1+2              | .40                                                                        |       |
| 19   | 8:20  | 1+2              | .35                                                                        |       |
| 20   | 8:40  | 1+3              | .38                                                                        |       |
| 21   | 9:05  | 2+3              | .41                                                                        |       |
| 22   | 8:15  | 2                | .35                                                                        |       |
| 23   | 8:15  | 2                | .40                                                                        |       |
| 24   | 8:05  | 2                | .35                                                                        |       |
| 25   | 8:10  | 2                | .33                                                                        |       |
| 26   | 8:20  | 2                | .35                                                                        |       |
| 27   | 8:45  | 2                | .38                                                                        |       |
| 28   | 8:45  | 1+3              | .33                                                                        |       |
| 29   | 9:15  | 1                | .32                                                                        |       |
| 30   | 10:40 | 2                | .33                                                                        |       |
| 31   | 10:45 | 2                | .31                                                                        |       |

Was the chlorine residual ever less than the required minimum residual of 0.20 mg/L? ☐ Yes ☒ No

If yes, what was the longest time period until the required level was restored? hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

**GWS Serving 3,300 or Fewer**

If yes, did you monitor every four hours until the residual returned to 0.20 mg/L as required? ☐ Yes ☐ No

Attach those results and submit them with this form.

**GWS Serving More Than 3,300**

Did continuous monitoring equipment fail at any time this reporting month? ☐ Yes ☐ No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? ☐ Yes ☐ No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed:

/ /

Date it was returned to service:

/ /

Printed Name: brian Bettis

Title: Bay City Water Technician

Operator Certification #: T-09089

Signature: 

Phone #: (503) 377-4121

OR

Date: 09 / 05 / 2025

Small Groundwater System ☐