

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name Bay City Water System

PWS ID# 4 1 00079

Month/Year 12/2025 Entry Point: Wells

Required Minimum Residual 0.20 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	8:20	2	.44	
2	8:30	1+2	.29	
3	8:30	1+2	.38	
4	8:30	2	.36	
5	8:30	1	.38	
6	8:35	2	.38	
7	10:20	1	.41	
8	8:00	1	.41	
9	8:20	1	.32	
10	8:55	2	.31	
11	8:00	1	.35	
12	8:30	2	.34	
13	9:45	1	.36	
14	9:45	1	.38	
15	9:10	2	.36	
16	8:50	1+2	.30	
17	8:45	2	.37	
18	8:40	-	.30	
19	8:20	1	.37	
20	1:00	1	.30	
21	10:30	2	.36	
22	9:15	1+2	.40	
23	9:30	1	.32	
24	9:15	1	.34	
25	8:30	2	.42	
26	11:00	2	.40	
27	9:00	2	.36	
28	9:00	1	.48	
29	8:30	1	.41	
30	8:30	2	.35	
31	7:45	1	.39	


Was the chlorine residual ever less than the required minimum residual of 0.20 mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to 0.20 mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach those results and submit them with this form.</i></p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach grab sample results and submit them with this form.</i></p>	<p>Date continuous monitoring equipment failed: / /</p> <p>Date it was returned to service: / /</p>
--	---	---

Printed Name: brian Bettis

Title: Bay City Water Technician

Operator Certification #: T-09089

Signature: 

Phone #: (503) 377-4121

OR

Date: 01 / 05 / 2026

Small Groundwater System