

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name	Bay City Water System	PWS ID#	4 1 00079
Month/Year	06/2021	Entry Point:	Wells
		Required Minimum Residual	0.20 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	8:10	1	.30	
2	9:05	1	.31	
3	8:30	1	.32	
4	9:15	1	.31	
5	9:15	2	.32	
6	8:35	1	.31	
7	8:35	1	.33	
8	10:30	2	.31	
9	7:55	1	.30	
10	7:45	2	.31	
11	8:50	1	.30	
12	11:30	1	.32	
13	9:20	2	.31	
14	8:05	2	.31	
15	8:30	2	.32	
16	8:15	2	.32	
17	11:10	1	.31	
18	8:25	1	.26	
19	7:25	1	.24	
20	9:20	1	.27	
21	8:40	1	.25	
22	7:30	1	.27	
23	7:50	2	.26	
24	8:25	1	.24	
25	10:55	1+2	.26	
26	9:35	2	.25	
27	8:00	2	.25	
28	7:45	1	.24	
29	8:10	1	.25	
30	8:45	1	.25	
31				

Was the chlorine residual ever less than the required minimum residual of 0.20 mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to 0.20 mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach those results and submit them with this form.</i></p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach grab sample results and submit them with this form.</i></p>	<p>Date continuous monitoring equipment failed: / /</p> <p>Date it was returned to service: / /</p>
----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	-------------------------------------------------------------------------------------------------------------

Printed Name: brian Bettis	Title: Bay City Water Technician	Operator Certification #: T-09089
Signature:	Phone #: (503) 377-4121	OR
Date: 07 / 06 / 2021		Small Groundwater System <input type="checkbox"/>