

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name Bay City Water System

PWS ID# 4 1 00079

Month/Year 07/2021 Entry Point: Wells

Required Minimum Residual 0.20 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	9:00	1	.26	
2	8:30	1	.26	
3	10:30	1	.25	
4	8:55	1	.27	
5	9:45	1	.26	
6	8:55	1	.26	
7	8:20	1	.28	
8	8:10	1	.25	
9	9:25	2	.26	
10	9:25	2	.26	
11	10:00	1+2	.27	
12	8:30	2	.27	
13	9:10	2	.27	
14	8:15	2	.25	
15	9:20	2	.24	
16	8:20	1+2	.22	
17	8:00	2	.20	
18	8:50	1	.30	
19	12:00	1+2	.32	
20	9:05	1+2	.26	
21	7:25	1	.26	
22	8:30	1	.27	
23	9:10	1	.25	
24	8:30	1	.22	
25	8:15	1+2	.28	
26	6:40	1	.30	
27	8:20	2	.33	
28	9:05	2	.32	
29	8:25	1	.33	
30	9:00	2	.31	
31	10:50	1	.27	

Was the chlorine residual ever less than the required minimum residual of 0.20 mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to 0.20 mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach those results and submit them with this form.</i></p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach grab sample results and submit them with this form.</i></p>	<p>Date continuous monitoring equipment failed: / /</p> <p>Date it was returned to service: / /</p>
--	---	---

Printed Name: brian Bettis Signature: <u>B. Bettis</u> Date: 08 / 02 / 2021	Title: Bay City Water Technician Phone #: (503) 377-4121	Operator Certification #: T-09089 OR Small Groundwater System <input type="checkbox"/>
---	---	--