

**State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems**

System Name Bay City Water System

PWS ID# 4 1 00079

Month/Year 09/2021 Entry Point: Wells

Required Minimum Residual 0.20 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	8:40	1+2	.36	
2	6:45	2	.34	
3	9:15	1	.34	
4	9:25	2	.33	
5	10:00	2	.33	
6	10:15	1+2	.34	
7	8:45	1	.27	
8	8:20	2	.30	
9	9:10	1	.30	
10	9:30	2	.31	
11	9:40	1	.32	
12	10:05	2	.31	
13	9:30	2	.34	
14	7:20	1	.31	
15	7:55	2	.31	
16	7:55	2	.30	
17	9:00	1	.38	
18	8:40	1	.37	
19	9:15	1	.30	
20	8:20	2	.33	
21	8:30	2	.34	
22	8:20	2	.32	
23	7:50	1	.35	
24	8:30	2	.31	
25	8:50	2	.28	
26	6:30	1	.31	
27	8:40	1	.32	
28	9:25	1	.30	
29	8:50	1+2	.32	
30	8:40	2	.32	
31				

Was the chlorine residual ever less than the required minimum residual of 0.20 mg/L?  Yes  No  
 If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p><b>GWS Serving 3,300 or Fewer</b></p> <p>If yes, did you monitor every four hours until the residual returned to 0.20 mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach those results and submit them with this form.</i></p>	<p><b>GWS Serving More Than 3,300</b></p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach grab sample results and submit them with this form.</i></p>	<p>Date continuous monitoring equipment failed: / /</p> <p>Date it was returned to service: / /</p>
--	---	---

Printed Name: brian Bettis

Title: Bay City Water Technician

Operator Certification #: T-09089

Signature: B. Bettis

Phone #: (503) 377-4121

OR

Date: 10 / 01 / 2021

Small Groundwater System