

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name Bay City Water System

PWS ID# 4 1 00079

Month/Year 12/2021 Entry Point: Wells

Required Minimum Residual 0.20 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	8:10	1	.30	
2	8:30	1	.35	
3	8:05	2	.32	
4	9:07	1	.27	
5	9:30	2	.34	
6	7:40	2	.33	
7	8:00	1	.30	
8	8:05	2	.34	
9	8:30	2	.33	
10	8:15	1	.31	
11	10:00	2	.33	
12	9:30	1	.30	
13	8:40	2	.34	
14	8:25	1	.30	
15	8:20	2	.34	
16	8:40	1	.30	
17	8:15	1	.30	
18	9:40	1	.30	
19	10:00	1	.30	
20	9:00	2	.32	
21	8:25	2	.32	
22	8:25	2	.32	
23	8:05	2	.32	
24	10:15	2	.32	
25	8:00	2	.33	
26	8:30	-	.31	
27	9:40	2	.33	
28	8:25	2	.32	
29	9:10	1	.30	
30	8:50	1	.31	
31	7:35	1	.35	

Was the chlorine residual ever less than the required minimum residual of 0.20 mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to 0.20 mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach those results and submit them with this form.</i></p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach grab sample results and submit them with this form.</i></p>	<p>Date continuous monitoring equipment failed: / /</p> <p>Date it was returned to service: / /</p>
--	---	---

Printed Name: brian Bettis

Title: Bay City Water Technician

Operator Certification #: T-09089

Signature: 

Phone #: (503) 377-4121

OR

Date: 01 / 04 / 2022

Small Groundwater System