

**State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems**

System Name	Bay City Water System	PWS ID#	4 1 00079
Month/Year	02/2022	Entry Point:	Wells
		Required Minimum Residual	0.20 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	8:10	1	.32	
2	8:50	2	.30	
3	8:25	2	.33	
4	8:20	2	.34	
5	9:15	2	.33	
6	8:20	-	.35	
7	8:30	1	.32	
8	8:05	1	.33	
9	8:15	2	.30	
10	6:40	1	.30	
11	6:40	1	.36	
12	10:35	1	.29	
13	8:25	2	.32	
14	8:00	2	.29	
15	7:50	2	.33	
16	8:45	-	.28	
17	8:15	2	.32	
18	7:45	2	.31	
19	8:00	-	.28	
20	7:05	2	.30	
21	9:25	2	.34	
22	8:45	-	.44	
23	9:10	1	.33	
24	8:15	2	.29	
25	9:25	1	.35	
26	10:20	1	.36	
27	11:05	2	.35	
28	8:15	1	.33	
29				
30				
31				

Was the chlorine residual ever less than the required minimum residual of 0.20 mg/L?  Yes  No  
 If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p><b>GWS Serving 3,300 or Fewer</b></p> <p>If yes, did you monitor every four hours until the residual returned to 0.20 mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach those results and submit them with this form.</i></p>	<p><b>GWS Serving More Than 3,300</b></p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach grab sample results and submit them with this form.</i></p>	<p>Date continuous monitoring equipment failed: / /</p> <p>Date it was returned to service: / /</p>
--	---	---

Printed Name: brian Bettis	Title: Bay City Water Technician	Operator Certification #: T-09089
Signature:	Phone #: (503) 377-4121	OR
Date: 03 / 02 / 2022		Small Groundwater System <input type="checkbox"/>