

**State of Oregon Drinking Water Services  
Monthly Disinfection Report for Ground Water Systems**

System Name \_\_\_\_\_ Boardman, City of \_\_\_\_\_ PWS ID# 41 00130  
 Month/Year 3 / 2024 Entry Point: EP-A for Ranney Collector Wells Required Minimum Residual 0.2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	7:00	Col 1 & 2	0.86	
2	7:48	Col 1 & 2	0.88	
3	7:22	Col 1 & 2	0.85	
4	7:09	Col 1 & 2	0.86	
5	7:12	Col 1 & 2	0.85	
6	7:00	Col 1 & 2	0.86	
7	7:00	Col 1 & 2	0.84	
8	7:02	Col 1 & 2	0.82	
9	7:10	Col 1 & 2	0.76	
10	7:30	Col 1 & 2	0.79	
11	7:00	Col 1 & 2	0.78	
12	7:01	Col 1 & 2	0.88	
13	7:00	Col 1 & 2	0.85	
14	7:02	Col 1 & 2	0.86	
15	7:00	Col 1 & 2	0.88	
16	8:00	Col 1 & 2	0.94	
17	8:00	Col 1 & 2	0.93	
18	7:00	Col 1 & 2	1.03	
19	7:00	Col 1 & 2	0.88	
20	7:14	Col 1 & 2	1.00	
21	7:10	Col 1 & 2	0.85	
22	7:15	Col 1 & 2	0.84	
23	7:32	Col 1 & 2	0.79	
24	7:30	Col 1 & 2	0.79	
25	7:00	Col 1 & 2	0.79	
26	7:20	Col 1 & 2	0.75	
27	7:00	Col 1 & 2	0.72	
28	7:11	Col 1 & 2	0.86	
29	7:09	Col 1 & 2	0.83	
30	7:45	Col 1 & 2	0.94	
31	7:37	Col 1 & 2	0.88	

Was the chlorine residual ever less than the required minimum residual of 0.2 mg/L?  Yes  No  
 If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ Hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

**GWS Serving 3,300 or Fewer**  
 If yes, did you monitor every four hours until the residual returned to 0.2 mg/L as required?  Yes  No  
 Attach those results and submit them with this form.

**GWS Serving More Than 3,300**  
 Did continuous monitoring equipment fail at any time this reporting month?  Yes  No  
 If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required?  Yes  No  
 Attach grab sample results and submit them with this form.  
 Date continuous monitoring equipment failed: \_\_\_\_\_  
 Date it was returned to service: \_\_\_\_\_

Printed Name: Luis Campos Title: Public works Lead  
 Signature: \_\_\_\_\_ Phone #: (571) 701-8880 Operator Certification #: 90039  
 Date: 4/12/2024

# Ranney (Raw) Stations Log

For the Month of:

March

Date	Time	Initials	Collector #1			Collector #2			Total Hours	Collector #2			Flow Meters			Daily Coll. Flows					
			#1	#2	#3	#1	#2	#3		#1	#2	#3	GPM	Total	Daily		GPM	Total	Daily		
1	7:10	DP	45	0	0	0	0	0	193	0	4	0	0	4	5350	153403	1095	3485	250795	1425	2570
2	7:55	NA	46	0	0	1	0	0	196	0	3	0	0	4	5701	155076	1123	3256	257246	1451	2574
3	7:25	NA	47	0	0	1	0	0	199	0	3	0	0	4	5797	156001	975	3281	253617	1371	2346
4	7:09	DP	48	0	0	0	0	0	202	0	3	0	0	3	5781	157030	1629	3210	255142	1525	2554
5	7:10	DP	48	0	0	1	0	0	206	0	4	0	0	5	5766	158211	1181	3320	256591	1449	2630
6	7:10	DP	49	0	0	1	0	0	209	0	3	0	0	4	5790	159312	1161	3318	258094	1503	2604
7	7:10	DP	50	0	0	1	0	0	212	0	3	0	0	4	5795	160382	1070	3415	259592	1498	2568
8	7:12	J.C.	50	0	0	6	0	0	216	0	4	0	0	4	5763	161505	1123	3300	261041	1449	2572
9	7:12	DP	51	0	0	1	0	0	219	0	3	0	0	4	5695	162575	1020	3418	262530	1489	2589
10	7:14	DP	52	0	0	1	0	0	222	0	3	0	0	4	5425	163573	998	3340	263585	1355	2353
11	7:10	J.C.	53	0	0	1	0	0	225	0	3	0	0	4	5718	164531	958	3287	265328	1443	2461
12	7:11	J.C.	53	0	0	0	0	0	228	0	3	0	0	3	5800	165565	1134	3318	266862	1534	2668
13	7:10	J.C.	54	0	0	1	0	0	232	0	4	0	0	5	3768	166493	1028	3414	268343	1481	2509
14	7:13	J.C.	55	0	0	1	0	0	235	0	3	0	0	4	3296	167712	1019	3320	269873	1530	2549
15	7:09	J.C.	56	0	0	1	0	0	238	0	3	0	0	4	3788	168790	1078	3356	271379	1506	2584
16	8:10	J.C.	56	0	0	6	0	0	242	0	4	0	0	4	3776	170299	1459	3374	272800	1421	2880
17	8:10	AT	57	0	0	1	0	0	246	0	4	0	0	5	5710	171514	1265	3252	274311	1511	2776
18	7:10	DP	58	0	0	1	0	0	251	0	5	0	0	6	4700	172962	1448	3620	275657	1346	2794
19	7:09	J.C.	59	0	0	1	0	0	256	0	5	0	0	6	4963	174746	1784	3540	276955	1298	3082
20	7:14	NA	59	0	0	0	0	0	262	0	6	0	0	6	4780	176568	1822	3305	278268	1313	3135
21	7:16	DP	60	0	0	1	0	0	266	0	4	0	0	5	5615	177942	1374	3578	279725	1457	2831
22	7:25	NA	61	0	0	1	0	0	270	0	4	0	0	5	4931	179399	1457	3259	281270	1545	3002
23	7:42	S	62	0	0	1	0	0	274	0	4	0	0	5	5445	180682	1283	3262	282222	1452	4214
24	8:05	9	62	0	0	0	0	0	278	0	4	0	0	4	5110	181817	1035	3318	284256	1534	4852
25	7:10	DP	63	0	0	1	0	0	281	0	3	0	0	4	5720	182839	1022	3410	285739	1481	2503
26	7:11	NA	64	0	0	1	0	0	286	0	5	0	0	6	5738	184388	1549	3354	287172	1395	2944
27	7:10	DP	65	0	0	1	0	0	292	0	6	0	0	7	5720	186481	2093	4181	288940	1358	3985
28	7:21	NA	65	0	0	0	0	0	296	0	4	0	0	4	5711	187944	1463	3810	290382	1392	2955
29	7:18	NA	65	0	0	0	0	0	300	0	4	0	0	4	5820	189103	1159	3731	291602	1220	3379
30	7:53	J.C.	67	0	0	2	0	0	307	0	7	0	0	9	5787	191414	2311	3822	292679	1077	3388
31	7:43	J.C.	67	0	0	0	0	0	314	0	7	0	0	7	5371	193734	2320	3744	293731	1052	3372