

State of Oregon Drinking Water Services
Monthly Disinfection Report for Ground Water Systems

System Name Boardman, City of PWS ID# 4 1 00130
 Month/Year 7 2024 Entry Point: EP-A for Ranney Collector Wells Required Minimum Residual 0.2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	7:00	Col 1 & 2	0.79	
2	7:10	Col 1 & 2	0.78	
3	7:10	Col 1 & 2	0.78	
4	6:45	Col 1 & 2	0.76	
5	7:13	Col 1 & 2	0.78	
6	8:16	Col # 1 & 2	0.79	
7	7:46	Col # 1 & 2	0.82	
8	7:16	Col 1 & 2	0.81	
9	7:10	Col 1 & 2	0.75	
10	7:10	Col 1 and 2	0.92	
11	7:10	Col 1 and 2	0.86	
12	7:10	Col 1 and 2	0.83	
13	7:00	Col. 1 and 2	0.91	
14	7:50	Col. 1 and 2	0.90	
15	7:20	Col. 1 and 2	0.85	
16	7:15	Col 1 & 2	1.16	
17	7:00	Col 1 & 2	1.12	
18	7:00	Col 1 & 2	0.79	
19	7:00	Col 1 & 2	0.78	
20	7:25	Col 1 & 2	0.80	
21	7:22	Col 1 & 2	0.74	
22	7:21	Col 1 & 2	0.73	
23	7:23	Col 1 & 2	0.72	
24	7:15	Col 1 and 2	0.92	
25	7:55	Col 1 and 2	0.89	
26	7:00	Col 1 & 2	0.94	
27	6:00	Col 1 & 2	0.90	
28	7:10	Col 1 & 2	0.89	
29	7:10	Col 1 & 2	0.95	
30	7:13	Col 1 & 2	0.87	
31	7:10	Col 1 & 2	0.78	

Was the chlorine residual ever less than the required minimum residual of 0.2 mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ Hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer
 If yes, did you monitor every four hours until the residual returned to 0.2 mg/L as required? Yes No
 Attach those results and submit them with this form.

GWS Serving More Than 3,300
 Did continuous monitoring equipment fail at any time this reporting month? Yes No
 If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? Yes No
 Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed: _____/_____/_____
 Date it was returned to service: _____/_____/_____

Printed Name: Luis Campos Title: Public Works Lead
 Signature: _____ Phone #: (541) 701-8880 Operator Certification #: 90039
 Date: 8 / 7 / 24

Ranney (Raw) Stations Log

For the Month of: July

Date	Time	Initials	Collector #1			Collector #2			Total Hours	Flow Meters			Daily Coll. Flows						
			#1	#2	#3	#1	#2	#3		GPM	Daily	GPM		Total					
1	7:20	HS	134	588	0	0	2	0	0	0	850	4	4	351380	2317	3260	534590	3512	5829
2	7:25	HS	136	588	0	0	2	0	0	0	850	4	4	353697	1984	3252	538102	4191	6175
3	7:20	HS	138	588	0	0	2	0	0	0	863	4	4	355681	1730	3240	542293	4191	5886
4	6:52	J.C	141	588	0	0	3	0	0	0	860	4	4	356911	1583	3214	551492	4543	6126
5	7:21	N.C.	143	588	0	0	2	0	0	0	871	4	4	358494	1491	3260	556190	4698	6189
6	8-9	S	145	588	0	0	2	0	0	0	875	4	4	359985	1480	3219	560944	4774	6454
7	7:50	S	148	588	0	0	3	0	0	0	880	4	4	361665	1404	3235	565524	4660	6064
8	7:20	N.C.	150	588	0	0	2	0	0	0	884	4	4	363071	1743	3232	570076	4552	6295
9	7:10	SP	153	588	0	0	3	0	0	0	890	4	4	364814	3194	3200	574666	4590	7784
10	7:10	L.P.	155	588	0	0	2	0	0	0	899	4	4	368008	2816	3163	579312	4644	7462
11	7:10	L.P.	157	588	0	0	2	0	0	0	899	4	4	370824	3655	3173	583963	4651	8306
12	7:10	L.P.	160	588	0	0	3	0	0	0	918	4	4	374479	2202	3232	588533	4570	6772
13	7:10	HF	162	588	0	0	2	0	0	0	924	4	4	376681	2153	3205	593057	4524	6677
14	7:10	HF	165	588	0	0	3	0	0	0	930	4	4	378834	2447	3208	597893	4836	7283
15	7:10	L.P.	167	588	0	0	2	0	0	0	937	4	4	381281	3057	3220	602426	4453	7510
16	7:20	HS	169	588	0	0	2	0	0	0	946	4	4	384037	4609	3703	606991	35435	4618
17	7:15	L.P.	172	588	0	0	3	0	0	0	960	4	4	394244	5622	3250	611634	4643	9820
18	7:15	L.P.	174	588	0	0	2	0	0	0	975	4	4	399204	5519	3242	616230	4596	9586
19	7:31	N.C.	177	588	0	0	3	0	0	0	989	4	4	404723	5456	3220	620877	4647	10166
20	7:35	N.C.	179	588	0	0	2	0	0	0	1005	4	4	410179	4984	3221	625618	4741	10197
21	7:31	N.C.	181	588	0	0	2	0	0	0	1021	4	4	415163	4617	3224	630171	4553	9537
22	7:15	HS	184	588	0	0	3	0	0	0	1036	4	4	419780	4607	3231	634727	4556	9173
23	7:23	HS	186	588	0	0	2	0	0	0	1049	4	4	424420	3270	3207	639329	4607	9792
24	7:15	L.P.	189	588	0	0	3	0	0	0	1062	4	4	428090	3259	3218	643958	4629	8299
25	7:25	L.P.	191	588	0	0	2	0	0	0	1073	4	4	431849	3225	3225	648576	4618	8377
26	7:10	J.C	193	588	0	0	2	0	0	0	1084	4	4	434766	2922	3193	653204	4628	7550
27	6:10	JP	196	588	0	0	3	0	0	0	1092	4	4	437542	2776	3269	657630	4426	7202
28	7:20	JP	198	588	0	0	2	0	0	0	1100	4	4	440903	3361	3200	662551	4921	8282
29	7:10	HS	201	588	0	0	3	0	0	0	1110	4	4	443671	2768	3201	667109	4558	7376
30	7:20	L.P.	203	588	0	0	2	0	0	0	1118	4	4	446465	2794	3180	671752	4643	7823
31	7:10	HS	205	588	0	0	2	0	0	0	1126	4	4	449061	3106	3225	676405	4652	9295