

State of Oregon Drinking Water Services
Monthly Disinfection Report for Ground Water Systems

System Name Boardman, City of PWS ID# 41 00130
 Month/Year 08 / 2024 Entry Point: EP-A for Ranney Collector Wells Required Minimum Residual 0.2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	7:00	col 1 & 2	0.78	
2	7:15	col 1 & 2	0.83	
3	8:00	col 1 & 2	0.83	
4	7:30	col 1 & 2	1.17	
5	7:15	col 1 & 2	1.10	
6	7:10	col 1 & 2	1.07	
7	7:12	col 1 & 2	1.08	
8	7:15	col 1 & 2	1.09	
9	7:15	col 1 & 2	1.07	
10	7:22	col 1 & 2	1.03	
11	7:45	col 1 & 2	1.03	
12	7:48	col 1 & 2	1.00	
13	7:20	col 1 & 2	.99	
14	7:20	col 1 & 2	1.04	
15	7:10	col 1 & 2	1.01	
16	7:25	col 1 & 2	1.07	
17	8:05	col 1 & 2	1.01	
18	8:06	col 1 & 2	1.03	
19	7:02	col 1 & 2	1.00	
20	7:07	col 1 & 2	0.90	
21	7:20	col 1 & 2	0.93	
22	7:30	col 1 & 2	0.79	
23	7:30	col 1 & 2	0.82	
24	7:02	col 1 & 2	1.04	
25	7:45	col 1 & 2	1.00	
26	7:00	col 1 & 2	1.06	
27	7:10	col 1 & 2	.99	
28	7:15	col 1 & 2	.89	
29	7:40	col 1 & 2	0.88	
30	7:02	col 1 & 2	0.89	
31	7:30	col 1 & 2	0.88	

Was the chlorine residual ever less than the required minimum residual of 0.2 mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ Hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer
 If yes, did you monitor every four hours until the residual returned to 0.2 mg/L as required? Yes No
 Attach those results and submit them with this form.

GWS Serving More Than 3,300
 Did continuous monitoring equipment fail at any time this reporting month? Yes No
 If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? Yes No
 Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed: _____/_____/_____
 Date it was returned to service: _____/_____/_____

Printed Name: Luis Campos Title: Public Works Leader
 Signature: _____ Phone #: (541) 701-8880 Operator Certification #: 90039
 Date: 7 / 15 / 24

Ranney (Raw) Stations Log

For the Month of: August

Date	Time	Initials	Total Pump Hours			Collector #1			Collector #2			Total Hours	Flow Meters			Daily Coll. Flows						
			#1	#2	#3	#1	#2	#3	#1	#2	#3		Collector #2	Collector #1								
17:00	L.P.		209	588	0	x	1	0	0	0	1136	4	x	13	x	5820	453828	4167	3234	651027	4272	8839
27:02	U.S.		218	588	0	0	3	0	0	0	1161	4	13	0	16	5812	458407	4579	3167	685675	4508	9177
3:10	U.S.		215	588	0	0	2	0	0	0	1177	4	16	0	18	5797	463908	5501	3190	690446	4271	10272
4:10	U.S.		212	588	0	0	2	0	0	0	1189	4	12	0	14	5791	468035	4127	3209	695045	4599	8726
5:15	L.P.		220	588	0	0	3	0	0	0	1201	4	12	0	15	5813	472222	4292	3183	699452	4412	5704
6:15	U.S.		222	588	0	0	2	0	0	0	1215	4	14	0	16	5815	476958	4635	3205	701057	4600	9235
7:10	U.S.		225	588	0	0	3	0	0	0	1228	4	13	0	16	5812	481655	4630	3165	708691	4634	9354
8:10	U.S.		227	588	0	0	2	0	0	0	1240	4	12	0	14	5816	485541	2856	3264	713318	4627	8513
9:20	J.P.		229	588	0	0	2	0	0	0	1253	4	13	0	14	5816	490121	4580	3195	712923	4605	9185
10:15	U.S.		232	588	0	0	3	0	0	0	1265	4	12	0	15	5810	494356	4235	3263	720554	4633	8808
11:30	U.S.		234	588	0	0	2	0	0	0	1278	4	13	0	15	5809	498628	4272	3224	727186	4630	8902
12:00	L.P.		237	588	0	0	3	0	0	0	1290	4	12	0	15	5807	502764	4136	3202	731775	4589	8725
13:10	U.S.		239	588	0	0	2	0	0	0	1301	4	11	0	13	5797	506727	3963	3167	736442	4607	8630
14:30	L.P.		241	588	0	0	2	0	0	0	1312	4	11	0	13	5792	510454	3727	3155	741069	4627	8354
15:10	J.P.		244	588	0	0	3	0	0	0	1323	4	11	0	14	5790	514348	3894	3181	745790	4621	8515
16:15	U.S.		246	588	0	0	2	0	0	0	1334	4	11	0	13	5787	518194	3849	3200	750366	4616	8405
17:12	U.S.		249	588	0	0	3	0	0	0	1345	4	11	0	14	5817	521909	3712	3282	755106	4800	8512
18:11	U.S.		251	588	0	0	8	0	0	0	1356	4	11	0	13	5799	525658	3749	3166	759737	4631	8386
19:15	U.S.		253	588	0	0	2	0	0	0	1366	4	10	0	12	5791	529263	3605	3192	764177	4440	7672
20:12	U.S.		256	588	0	0	3	0	0	0	1377	4	11	0	14	5807	532953	3690	3166	768754	4572	8267
21:15	L.P.		258	588	0	0	2	0	0	0	1389	4	12	0	14	5807	537024	4071	3158	773382	4628	8609
22:15	L.P.		261	588	0	0	3	0	0	0	1398	4	9	0	12	5807	540142	3118	3290	778036	4654	7772
23:15	L.P.		263	588	0	0	2	0	0	0	1409	4	11	0	13	5811	544104	3962	3182	782635	4599	8561
24:11	U.S.		263	607	0	0	0	19	0	0	1416	7	7	3	13	5819	547122	3018	3135	786261	3626	6644
25:16	U.S.		263	697	0	0	0	20	0	0	1425	7	9	0	13	5814	550879	3157	3098	789786	3725	6882
26:10	L.P.		263	650	0	0	0	23	0	0	1431	7	6	0	12	5815	552016	1937	3098	792520	4324	6861
27:10	L.P.		263	671	0	0	0	21	0	0	1440	7	9	0	13	3605	555335	3119	3098	794269	3959	7078
28:10	U.S.		263	692	0	0	0	21	0	0	1448	7	8	0	12	5814	558126	2794	3077	802256	3987	6781
29:10	L.P.		263	716	0	0	0	24	0	0	1458	7	7	0	13	5812	560646	2517	3128	807284	4528	7043
30:10	L.P.		263	740	0	0	0	24	0	0	1463	7	7	0	13	5811	563344	2718	3128	811292	4508	7225
31:10	J.P.		263	765	0	0	0	25	0	0	1471	7	8	0	13	5824	566040	2676	3678	815968	4676	7352