

State of Oregon Drinking Water Services
Monthly Disinfection Report for Ground Water Systems

System Name Boardman, City of PWS ID# 41 00130
 Month/Year 12 / 2024 Entry Point: EP-A for Ranney Collector Wells Required Minimum Residual 0.2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	8:35	col 1 & 2	0.88	
2	7:15	col 2 & 2	0.88	
3	7:00	col 1 & 2	0.85	
4	7:09	col 1 & 2	0.88	
5	7:15	col 2 & 2	0.84	
6	7:15	col 1 & 2	0.88	
7	7:05	col 1 & 2	0.83	
8	7:35	col 1 & 2	0.82	
9	7:30	col 1 & 2	0.83	
10	7:15	col 2 & 2	0.86	
11	7:15	col 2 & 2	0.83	
12	7:10	col 1 & 2	0.78	
13	7:15	col 2 col 2	0.77	
14	7:30	col 1 & col 2	0.83	
15	7:30	col 1 & 2	0.86	
16	7:20	col 1 & 2	0.82	
17	7:22	col 1 & 2	0.91	
18	7:15	col 1 & 2	0.88	
19	7:20	col 2 & 2	0.92	
20	7:30	col 1 & 2	0.95	
21	8:05	col 2 & 2	0.94	
22	8:05	col 2 & 2	0.88	
23	7:52	col 1 & 2	0.99	
24	7:10	col 1 & 2	0.96	
25	8:10	col 2 & 2	1.00	
26	8:10	col 2 & 2	1.02	
27	7:15	col 1 & 2	1.04	
28	8-	col 1 & 2	0.98	
29	7:14	col 1 & 2	0.94	
30	7:15	col 2 & 2	0.86	
31	7:00	col 1 & 2	0.84	

Was the chlorine residual ever less than the required minimum residual of 0.2 mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ Hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to 0.2 mg/L as required? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>
	<p>Date continuous monitoring equipment failed: _____</p> <p>Date it was returned to service: _____</p>

Printed Name: Luis Campos Title: Public Works Lead
 Signature: _____ Phone #: (541) 79-8886 Operator Certification #: 900039
 Date: 6 / 6 / 2024

Ranney (Raw) Stations Log

For the Month of: December

Date	Time	Initials	Collector #1			Collector #2			Total Hours	Total Hours	Flow Meters				Daily Coll. Flows							
			#1	#2	#3	#1	#2	#3			GPM	Daily	GPM	Total		Collector #1	Daily					
1	8:45		268	1937	0	0	0	0	0	1944	20	2	0	0	0	5129	729529	936	3123	49339	1733	2669
2	7:30		268	1946	0	0	0	0	0	1949	20	3	0	0	0	5115	730485	956	3038	50899	1560	2516
3	7:10		268	1954	0	0	0	0	0	1952	20	3	0	0	0	5201	731671	1186	3194	52363	1464	2650
4	7:28		268	1970	0	0	0	0	0	1955	20	3	0	0	0	5209	732617	946	3139	54049	1686	2632
5	7:30		268	1978	0	0	0	0	0	1959	20	4	0	0	0	5225	733951	1335	3142	55379	1325	2660
6	7:20		268	1984	0	0	0	0	0	1964	20	5	0	0	0	5129	735519	1567	3148	56446	1072	2639
7	7:28		268	1990	0	0	0	0	0	1968	20	4	0	0	0	5198	737058	1537	3214	57669	1223	2762
8	7:46		268	1996	0	0	0	0	0	1973	20	5	0	0	0	5216	738633	1575	3189	58763	1094	2669
9	7:23		268	2003	0	0	0	0	0	1977	20	4	0	0	0	5182	740086	1453	3239	60027	1264	2717
10	7:30		268	2010	0	0	0	0	0	1980	20	3	0	0	0	5844	741219	1133	3132	61459	1432	2565
11	7:30		268	2018	0	0	0	0	0	1984	20	4	0	0	0	5815	742307	1088	3129	62974	1515	2603
12	7:28		268	2024	0	0	0	0	0	1988	20	4	0	0	0	5344	743715	1408	3173	64077	1103	2511
13	7:20		268	2030	0	0	0	0	0	1992	20	4	0	0	0	5317	745130	1415	3198	65237	1160	2575
14	7:40 JP		268	2038	0	0	0	0	0	1995	20	3	0	0	0	5805	746356	1226	3215	66741	1504	2730
15	7:40 JP		268	2044	0	0	0	0	0	2000	20	5	0	0	0	5869	749013	1657	3320	67821	1080	2733
16	7:28 HS		268	2049	0	0	0	0	0	2005	20	5	0	0	0	5801	749581	1568	3189	68876	1055	2625
17	7:24 NA		268	2058	0	0	0	0	0	2008	20	3	0	0	0	5819	750642	1061	3280	70449	1573	2634
18	7:22 NA		268	2065	0	0	0	0	0	2012	20	4	0	0	0	5821	751955	1313	3192	71782	1333	2646
19	7:30 L.P.		268	2073	0	0	0	0	0	2016	20	4	0	0	0	5838	753296	1392	3133	73302	1520	2862
20	7:28 H7		268	2081	0	0	0	0	0	2019	20	3	0	0	0	5810	754283	987	3227	74904	1602	2589
21	8:10 L.P.		268	2089	0	0	0	0	0	2022	20	3	0	0	0	5801	755641	1358	3203	76544	1640	2998
22	8:20 L.P.		268	2096	0	0	0	0	0	2027	20	5	0	0	0	5819	757177	1536	3195	77789	1245	2781
23	7:24 H7		268	2104	0	0	0	0	0	2030	20	3	0	0	0	5451	758249	1072	3108	79350	1561	2633
24	7:21 NA		268	2111	0	0	0	0	0	2034	20	4	0	0	0	5421	759735	1486	3124	80724	1374	2860
25	8:20 L.P.		268	2120	0	0	0	0	0	2038	20	4	0	0	0	5423	760968	1233	3242	82424	1700	2933
26	8:20 L.P.		268	2129	0	0	0	0	0	2042	20	4	0	0	0	5791	762225	1257	3232	84071	1647	2904
27	7:25 NA		268	2139	0	0	0	0	0	2044	20	2	0	0	0	5829	763187	962	3291	85907	1836	2798
28	7:20 S		268	2149	0	0	0	0	0	2048	20	4	0	0	0	5781	764292	1105	3168	87788	1881	2906
29	7:20 S		268	2156	0	0	0	0	0	2052	20	4	0	0	0	5820	765817	1525	3240	89191	2403	3929
30	7:20 L.P.		268	2163	0	0	0	0	0	2057	20	0	0	0	0	5815	767429	1612	3148	90560	1369	2981
31	7:30 L.P.		268	2171	0	0	0	0	0	2061	20	4	0	0	0	5820	768921	1492	3197	91913	4353	2845