

**State of Oregon Drinking Water Services
Monthly Disinfection Report for Ground Water Systems**

System Name Boardman, City of PWS ID# 41 00130
 Month/Year 7 / 25 Entry Point: EP-A for Ranney Collector Wells Required Minimum Residual 0.2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	7:20	Col 1 & 2	0.89	
2	7:10	Col 1 & 2	0.90	
3	7:10	Col 1 & 2	0.90	
4	7:00	Col 1 & 2	0.93	
5	7:10	Col 1 & 2	0.85	
6	8:45	Col 1 & 2	0.88	
7	7:10	Col 1 & 2	1.01	
8	7:10	Col 1 & 2	0.88	
9	7:08	Col 1 & 2	0.88	
10	7:05	Col 1 & 2	0.93	
11	7:00	Col 1 & 2	0.99	
12	7:20	Col 1 & 2	0.95	
13	7:51	Col 1 & 2	0.93	
14	7:05	Col 1 & 2	0.95	
15	7:10	Col 1 & 2	1.03	
16	7:10	Col 1 & 2	0.92	
17	7:20	Col 1 & 2	0.93	
18	7:08	Col 1 & 2	1.04	
19	7:00	Col 1 & 2	1.01	
20	7:35	Col 1 & 2	0.97	
21	7:20	Col 1 & 2	0.91	
22	7:15	Col 1 & 2	0.87	
23	7:20	Col 1 & 2	0.91	
24	7:25	Col 1 & 2	0.87	
25	7:10	Col 1 & 2	0.92	
26	7:16	Col 1 & 2	0.88	
27	7:45	Col 1 & 2	0.92	
28	7:20	Col 1 & 2	0.89	
29	8:10	Col 1 & 2	0.93	
30	7:20	Col 1 & 2	0.97	
31	7:06	Col 1 & 2	1.00	

Was the chlorine residual ever less than the required minimum residual of 0.2 mg/L? ☒ Yes ☐ No

If yes, what was the longest time period until the required level was restored? _____ Hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer

If yes, did you monitor every four hours until the residual returned to 0.2 mg/L as required? ☒ Yes ☐ No

Attach those results and submit them with this form.

GWS Serving More Than 3,300

Did continuous monitoring equipment fail at any time this reporting month? ☒ Yes ☐ No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? ☒ Yes ☐ No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed: _____

Date it was returned to service: _____

Printed Name: Luis Campos

Title: Public Works Lead

Signature: _____

Phone #: (541) 701 8880

Date: 8 / 7 / 2025

Operator Certification #: 900039