

**State of Oregon Drinking Water Services  
Monthly Disinfection Report for Ground Water Systems**

System Name Boardman, City of PWS ID# 41 00130  
 Month/Year 9/12/25 Entry Point: EP-A for Ranney Collector Wells Required Minimum Residual 0.2 mg/L

| Date | Time  | Source(s) in use | Lowest free chlorine residual at entry point to distribution system (mg/L) | Notes |
|------|-------|------------------|----------------------------------------------------------------------------|-------|
| 1    |       |                  |                                                                            |       |
| 2    | 7:03  | col 1 & 2        | 0.86                                                                       |       |
| 3    | 7:20  | col 1 & 2        | 0.97                                                                       |       |
| 4    | 7:17  | col 1 & 2        | 0.98                                                                       |       |
| 5    | 7:20  | col 1 & 2        | 0.69                                                                       |       |
| 6    | 7:22  | col 1 & 2        | 0.94                                                                       |       |
| 7    | 8:15  | col 1 & 2        | 0.95                                                                       |       |
| 8    | 8:35  | col 1 & 2        | 0.93                                                                       |       |
| 9    | 7:06  | col 1 & 2        | 0.98                                                                       |       |
| 10   | 7:06  | col 1 & 2        | 0.87                                                                       |       |
| 11   | 7:05  | col 1 & 2        | 0.95                                                                       |       |
| 12   | 7:00  | col 1 & 2        | 0.89                                                                       |       |
| 13   | 7:00  | col 1 & 2        | 0.92                                                                       |       |
| 14   | 8:00  | col 1 & 2        | 0.90                                                                       |       |
| 15   | 7:00  | col 1 & 2        | 0.89                                                                       |       |
| 16   | 7:00  | col 1 & 2        | 0.92                                                                       |       |
| 17   | 7:00  | col 1 & 2        | 0.91                                                                       |       |
| 18   | 7:00  | col 1 & 2        | 0.98                                                                       |       |
| 19   | 8:00  | col 1 & 2        | 0.88                                                                       |       |
| 20   | 8:00  | col 1 & 2        | 0.88                                                                       |       |
| 21   | 7:30  | col 1 & 2        | 0.89                                                                       |       |
| 22   | 7:00  | col 1 & 2        | 0.93                                                                       |       |
| 23   | 7:10  | col 1 & 2        | 0.93                                                                       |       |
| 24   | 7:05  | col 1 & 2        | 1.00                                                                       |       |
| 25   | 07:04 | col 1 & 2        | 1.03                                                                       |       |
| 26   | 7:07  | col 1 & 2        | 1.04                                                                       |       |
| 27   | 7:06  | col 1 & 2        | 0.86                                                                       |       |
| 28   | 7:01  | col 1 & 2        | 0.89                                                                       |       |
| 29   | 7:05  | col 1 & 2        | 0.95                                                                       |       |
| 30   | 7:04  | col 1 & 2        | 0.80                                                                       |       |
| 31   | 7:00  | col 1 & 2        |                                                                            |       |

Was the chlorine residual ever less than the required minimum residual of 0.2 mg/L? ☒ Yes ☐ No

If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ Hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

**GWS Serving 3,300 or Fewer**

If yes, did you monitor every four hours until the residual returned to 0.2 mg/L as required? ☒ Yes ☐ No

Attach those results and submit them with this form.

**GWS Serving More Than 3,300**

Did continuous monitoring equipment fail at any time this reporting month? ☐ Yes ☒ No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? ☐ Yes ☒ No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed: \_\_\_\_/\_\_\_\_/\_\_\_\_

Date it was returned to service: \_\_\_\_/\_\_\_\_/\_\_\_\_

Printed Name: Luis Campes

Title: Assistant PWS Director

Signature: [Signature]

Phone #: (541) 741-8880

Operator Certification #: 900039

Date: 10/6/2025