

State of Oregon Drinking Water Services
Monthly Disinfection Report for Ground Water Systems

System Name City of Boardman PWS ID# 41 00130
 Month/Year 08/22 Entry Point: EP-A for Ranney Wells Required Minimum Residual 0.2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	6:00	TP	0.66	
2	5:52	TP	0.63	
3	5:59	TP	0.68	
4	7:20	TP	0.69	
5	7:00	TP	0.73	
6	7:55	TP	0.71	
7	8:00	TP	0.72	
8	7:00	TP	0.73	
9	7:25	TP	0.73	
10	7:17	TP	0.73	
11	7:31	TP	0.72	
12	7:08	TP	0.74	
13	7:44	TP	0.72	
14	9:19	TP	0.68	
15	7:13	TP	0.73	
16	7:31	TP	0.71	
17	7:20	TP	.68	
18	7:33	TP	.67	
19	7:20	TP	.61	
20	7:21	TP	.58	
21	8:34	TP	.74	
22	7:10	TP	.86	
23	7:03	TP	.61	
24	7:00	TP	.68	
25	6:43	TP	0.69	
26	7:16	TP	0.73	
27	7:50	TP	0.74	
28	7:43	TP	0.72	
29	6:32	TP	0.69	
30	7:09	TP	0.78	
31	7:15	TP	0.74	

Was the chlorine residual ever less than the required minimum residual of 0.2 mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ Hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer
 If yes, did you monitor every four hours until the residual returned to 0.2 mg/L as required? Yes No
 Attach those results and submit them with this form.

GWS Serving More Than 3,300
 Did continuous monitoring equipment fail at any time this reporting month? Yes No
 Date continuous monitoring equipment failed: _____/_____/_____
 If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? Yes No
 Date it was returned to service: _____/_____/_____
 Attach grab sample results and submit them with this form.

Printed Name: Kevin Kennedy Title: PWD
 Signature: [Signature] Phone #: (541) 481-9252
 Date: 09/06/2022

Operator Certification
 #: D/T-6106

Ranney (Raw) Stations Log

For the Month of: August 2022

Date	Time	Initials	Collector #1						Collector #2				Total Hours	Flow Meters						Daily Coll. Flows
			Total Pump Hours			Daily Hours			Total Pump Hrs.		Daily Hrs.			Collector #2			Collector #1			
			#1	#2	#3	#1	#2	#3	#1	#2	#1	#2		GPM	Total	Daily	GPM	Total	Daily	
Last Reading ==>			57	56	2	x	x	x	402	20	x	x	x	x	788072	x	x	88969	x	
1	5:53	J.C	59	56	2	2	0	0	415	20	13	0	15	5672	792660	4588	3153	893553	3934	8522
2	5:46	J.C	61	56	2	2	0	0	429	20	14	0	16	5735	797558	4898	3215	898023	4470	9368
3	5:53	J.C	64	56	2	3	0	0	446	20	17	0	20	5672	803309	5751	3145	902638	4615	10366
4	7:12	LE	66	56	2	2	0	0	464	20	18	0	20	5689	809322	6013	3218	906902	4264	10777
5	7:24	LE	67	56	2	1	0	0	470	32	14	12	26	5529	815330	6008	3139	909931	3029	9037
6	7:45	LF	70	56	2	3	0	0	481	35	11	3	17	5535	820169	4839	3124	913986	4055	8894
7	7:55	LF	71	57	2	1	1	0	498	35	17	0	19	5228	825863	5694	3244	916776	2790	8484
8	7:10	LE	73	57	2	2	0	0	513	35	15	0	17	5891	838714	4851	3245	920899	4123	8974
9	7:06	LE	75	62	2	2	5	0	527	38	15	3	25	5803	836558	5844	3170	925487	4588	10432
10	7:24	LE	78	62	2	3	0	0	540	38	13	0	16	5893	840723	4165	3199	920032	4745	8910
11	7:20	LE	80	63	2	2	1	0	552	38	12	0	15	5891	844926	4203	3142	934785	4553	8756
12	7:13	N.O	82	63	2	2	0	0	565	38	13	0	15	5793	849341	4415	3194	939373	4588	9003
13	7:52	S	85	63	2	3	0	0	578	38	13	0	16	5689	853437	4097	3140	944115	4742	7882
14	8:59	9	87	63	2	2	0	0	589	38	11	0	13	5671	857417	3980	3206	948377	4242	8242
15	7:14	LE	89	66	2	2	3	0	604	38	15	0	20	5780	862296	4879	3211	951602	3225	8104
16	7:35	LE	91	67	2	2	1	0	617	38	14	0	17	5791	866698	4402	3218	956368	4766	9168
17	7:25	LE	93	67	2	2	0	0	630	38	13	0	15	5777	871144	4446	3199	960955	4587	9033
18	7:40	LE	96	68	2	3	1	0	644	38	14	0	18	5810	875748	41604	3185	965720	4765	9369
19	7:28	N.O	98	70	2	2	2	0	656	38	12	0	16	5881	880646	4298	3206	970440	4790	9018
20	8:27	LE	101	70	2	3	0	0	668	38	12	0	15	5798	884020	3974	3112	975230	4790	8764
21	8:39	LE	103	71	2	2	1	0	681	38	13	0	16	5780	888431	4411	3189	979537	4307	8718
22	7:16	J.C	105	72	0	2	1	0	694	38	13	0	16	5762	892588	4157	3189	983851	4314	8471
23	7:08	LE	108	73	2	3	1	2	707	38	13	0	19	5801	896944	4356	3194	988490	4639	8995
24	7:05	LE	110	74	2	2	1	0	719	38	12	0	18	5791	901129	4185	3211	993142	4652	8837
25	6:46	J.C	112	75	2	2	1	0	731	38	12	0	15	5673	905172	4043	3190	997792	4650	8693
26	7:19	J.C	115	76	2	3	1	0	743	38	12	0	16	5801	909244	4072	3114	2468	4676	8748
27	7:53	J.C	117	76	2	2	0	0	754	38	11	0	13	5731	913026	3782	3213	7096	4628	8470
28	7:46	J.C	119	76	2	2	0	0	766	38	12	0	14	5816	916939	3913	3197	10585	3489	7402
29	6:35	J.C	121	77	2	2	1	0	777	38	11	0	14	5800	920736	3797	3202	14527	3942	7739
30	7:05	LE	123	78	2	2	1	0	789	38	12	0	15	5799	924652	3916	3157	19200	4673	8589
31	7:18	J.C	126	78	2	3	0	0	802	38	13	0	16	5828	929067	4415	3192	23859	4659	9074