

State of Oregon Drinking Water Services
Monthly Disinfection Report for Ground Water Systems

System Name City of Boardman PWS ID# 41 00130
Month/Year 9/22 Entry Point: EP-A for Ranney Wells Required Minimum Residual 0.2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	6:30	Col 1E2	.71	
2	7:03	Col 1E2	.71	
3	7:00	Col 1E2	0.71	
4	8:00	Col 1E2	0.69	
5	7:00	Col 1E2	0.70	
6	7:06	Col 1E2	0.74	
7	7:12	Col 1E2	0.73	
8	7:23	Col 1E2	.89	
9	7:37	Col #1E2	.86	
10	7:48	Col #1E2	.86	
11	7:31	Col #1E2	.85	
12	7:20	Col #1E2	.84	
13	7:24	Col #1E2	.82	
14	7:46	Col #1E2	.74	
15	6:45	Col #1E2	0.68	
16	7:00	Col #1E2	0.73	
17	7:55	Col #1E2	0.65	
18	8:16	Col #1E2	0.65	
19	7:13	Col #1E2	0.63	
20	7:01	Col #1E2	.66	
21	7:13	Col #1E2	0.68	
22	7:00	Col #1E2	.65	
23	7:24	Col #1E2	0.73	
24	7:15	Col #1E2	0.71	
25	7:05	Col #1E2	0.83	
26	7:01	Col #1E2	.72	
27	7:00	Col #1E2	0.74	
28	7:02	Col #1E2	.80	
29	7:16	Col #1E2	0.78	
30	7:06	Col #1E2	0.78	
31				

Was the chlorine residual ever less than the required minimum residual of 0.2 mg/L? ☐ Yes ☐ No
If yes, what was the longest time period until the required level was restored? _____ Hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer If yes, did you monitor every four hours until the residual returned to 0.2 mg/L as required? ☐ Yes ☐ No ☐ Attach those results and submit them with this form.	GWS Serving More Than 3,300 Did continuous monitoring equipment fail at any time this reporting month? ☐ Yes ☒ No If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? ☐ Yes ☐ No ☐ Attach grab sample results and submit them with this form.	Date continuous monitoring equipment failed: _____ Date it was returned to service: _____
--	---	---

Printed Name: Kevin Kennedy Title: PWD
Signature: [Signature] Phone #: (541) 481-9252
Date: 10/03/2022 Operator Certification #: D/T-6106

Ranney (Raw) Stations Log

For the Month of: September 2022

			Collector #1						Collector #2				Total Hours	Flow Meters						Daily Coll. Flows
			Total Pump Hours			Daily Hours			Total Pump Hrs.		Daily Hrs.			Collector #2			Collector #1			
Date	Time	Initials	#1	#2	#3	#1	#2	#3	#1	#2	#1	#2		GPM	Total	Daily	GPM	Total	Daily	
Last Reading ==>														x			x			
			126	78	2	x	x	x	802	38	x	x	x							
1	6:35	Le	128	80	2	2	2	0	816	38	14	0	18	5808	933574	4507	3160	28531	4672	9179
2	7:07	Le	131	81	2	3	1	0	829	38	13	0	17	5829	938128	4554	3196	33395	4864	7418
3	6:45	JF	133	81	2	2	0	0	842	38	13	0	15	5721	942637	4509	3250	37220	4875	9384
4	8:05	JF	134	82	2	1	1	0	855	38	13	0	15	5818	947028	4366	3208	40890	3628	7994
5	7:00	JF	136	82	2	2	0	0	868	38	13	2	15	5794	951475	4447	3148	44374	3476	7923
6	7:09	J.C	138	83	2	2	1	0	879	38	11	6	14	5793	955022	3547	3179	48764	4390	7937
7	7:18	Le	141	83	2	3	0	0	891	38	12	0	15	5783	959131	4109	3261	53142	4378	8487
8	7:30	Le	143	83	2	2	0	0	902	38	11	0	13	5398	962876	3715	3278	57663	4521	8266
9	7:35	N.Q.	145	84	2	2	1	0	914	38	12	0	15	5739	966636	3766	3280	61711	4048	7808
10	7:51	g	147	85	2	2	1	0	925	38	11	0	14	5820	970465	3829	3196	65176	3445	7894
11	7:50	g	148	85	2	1	0	0	936	38	11	0	13	5767	974113	3648	3224	68514	3338	6986
12	7:29	Le	150	86	2	2	1	0	947	38	11	0	14	5798	977693	3580	3271	72016	3502	7082
13	7:19	J.C	152	87	2	2	1	0	959	38	12	0	15	5760	981703	4010	3269	75374	3358	7568
14	6:50	J.C	154	87	2	2	0	0	969	38	16	0	12	5753	985309	3606	3195	78794	3420	7026
15	6:48	J.C	155	88	2	1	1	0	981	38	12	0	14	5813	989259	3950	3199	81663	2869	6819
16	7:04	Le	157	89	2	2	1	0	992	38	11	0	14	5829	992759	3500	3290	84971	3328	6828
17	7:58	J.C	158	90	2	1	1	0	1002	38	10	0	12	5769	996256	3491	3179	88073	3102	6593
18	8:19	J.C	159	91	2	1	1	0	1012	38	10	0	12	5777	999505	3255	3187	90575	2502	5757
19	7:12	J.C	160	92	2	1	1	0	1021	38	9	0	11	5768	2718	3213	3216	92787	2212	5425
20	7:05	Le	162	93	2	2	1	0	1031	38	10	0	13	5821	5926	3208	3221	95663	2876	6087
21	7:16	J.C	163	93	2	1	0	0	1041	38	10	0	11	5809	9179	3253	3345	98476	2813	6066
22	7:05	Le	164	94	2	1	1	0	1051	38	10	0	12	5791	12450	3271	3254	101130	2654	5925
23	7:27	J.C	166	95	2	2	1	0	1059	38	8	0	11	5779	15115	2665	3297	104363	3233	5898
24	7:23	Le	167	96	2	1	1	0	1069	38	10	0	12	5781	18473	3358	3187	107055	2692	6050
25	8:10	Le	169	96	2	2	0	0	1079	38	10	0	12	5779	22044	3571	3260	110605	2950	6521
26	7:04	Le	170	97	2	1	1	0	1090	38	11	0	13	5781	25627	3583	3193	112433	2428	6011
27	7:10	J.C	172	98	2	2	1	0	1099	38	9	0	12	5811	28548	2921	3178	115596	3163	6084
28	7:05	Le	173	99	2	1	1	0	1111	38	12	0	14	5810	32441	3893	5123	118223	2627	6520
29	7:14	J.C	174	100	2	1	1	0	1121	38	10	0	12	5758	35946	3505	3233	121027	2804	6309
30	7:09	J.C	175	101	2	1	1	0	1132	38	11	0	13	5775	39517	3571	3165	123557	2530	6101
31																				