

State of Oregon Drinking Water Services
Monthly Disinfection Report for Ground Water Systems

System Name City of Boardman PWS ID# 41 00130
 Month/Year 10/22 Entry Point: EP-A for Ranney Wells Required Minimum Residual 0.2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	8:05	Col. 1 and 2	0.82	
2	8:25	Col. 1 and 2	0.65	
3	7:19	col 1 and 2	0.56	
4	7:12	col 1 & 2	0.75	
5	7:09	col 1 & 2	0.74	
6	7:15	col 1 & 2	0.76	
7	6:39	col 1 & 2	0.74	
8	7:21	col 1 & 2	0.74	
9	7:21	col 1 & 2	0.65	
10	7:18	col 1 & 2	0.66	
11	7:03	col 1 & 2	0.45	
12	7:08	col 1 & 2	0.54	
13	7:16	col 1 & 2	0.59	
14	6:44	col 1 & 2	0.75	
15	6:24	col 1 & 2	0.77	
16	6:38	col 1 & 2	0.72	
17	7:13	col 1 & 2	0.78	
18	7:09	col 1 & 2	0.76	
19	7:05	col 1 & 2	0.78	
20	6:44	col 1 & 2	0.75	
21	7:04	col 1 & 2	0.69	
22	8:18	col 1 & 2	0.64	
23	8:15	col 1 & 2	0.64	
24	7:15	col 1 & 2	0.72	
25	7:07	col 1 & 2	0.70	
26	7:05	col 1 & 2	0.79	
27	7:12	col 1 & 2	0.77	
28	7:10	col 1 & 2	0.77	
29	7:15	col 1 & 2	0.78	
30	8:20	col 1 N 2	0.78	
31	8:10	col 1 N 2	0.78	

Was the chlorine-residual ever less than the required minimum residual of 0.2 mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ Hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer
 If yes, did you monitor every four hours until the residual returned to 0.2 mg/L as required? Yes No
 Attach those results and submit them with this form.

GWS Serving More Than 3,300
 Did continuous monitoring equipment fail at any time this reporting month? Yes No
 If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? Yes No
 Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed: _____
 Date it was returned to service: _____

Printed Name: Kevin Kennedy Title: PWD
 Signature: [Signature] Phone #: (541) 481-9252
 Date: 11/4/2022

Operator Certification
 #: D/T-6106

Ranney (Raw) Stations Log

For the Month of: October 2022

Date	Time	Initials	Collector #1						Collector #2						Total Hours	Total Hours	Daily Coll. Flows				
			Total Pump Hours			Daily Hours			Total Pump Hrs.			Daily Hrs.									
			#1	#2	#3	#1	#2	#3	#1	#2	#3	#1	#2	#3							
1	7:50	J.C.	175	101	2	2	1	0	1132	38	0	11	0	0	14	39517	3737	3756	123557	2485	5841
2	8:05	J.C.	177	102	2	1	0	0	1143	38	0	10	0	0	11	412254	32481	3300	128459	2412	5808
3	7:22	J.C.	178	102	2	1	0	0	1153	38	0	11	0	0	14	50187	3452	3273	130816	2357	5809
4	7:14	J.C.	179	104	2	1	0	0	1164	38	0	11	0	0	12	53852	3665	3250	133546	2730	6395
5	7:11	J.C.	180	104	2	1	0	0	1175	38	0	11	0	0	14	57660	3808	3273	136211	2665	6473
6	7:12	J.C.	182	105	2	2	0	0	1186	38	0	12	0	0	14	61753	4093	3196	138619	2488	6501
7	6:40	J.C.	183	106	2	1	0	0	1198	38	0	12	0	0	14	65550	3797	3256	140839	2220	6017
8	7:27	J.C.	184	107	2	1	0	0	1210	38	0	12	0	0	12	69104	3552	3258	143179	2346	5892
9	7:27	J.C.	185	108	2	1	0	0	1220	38	0	10	0	0	12	72716	3314	3241	145461	2282	5596
10	7:23	J.C.	186	109	2	1	0	0	1230	38	0	10	0	0	12	76986	3570	3221	147642	2181	5751
11	7:05	J.C.	187	109	2	1	0	0	1241	38	0	11	0	0	12	79191	3205	3129	150504	2922	6127
12	7:11	J.C.	188	110	2	2	0	0	1251	38	0	10	0	0	12	83020	3829	3257	152926	2362	6191
13	7:19	J.C.	190	112	2	1	0	0	1262	38	0	11	0	0	15	86503	3483	3229	155621	2695	6178
14	6:47	J.C.	191	113	2	1	0	0	1273	38	0	11	0	0	13	89941	3438	3459	157926	2305	5743
15	6:27	J.C.	192	114	2	1	0	0	1283	38	0	10	0	0	12	92852	2911	3496	160191	2265	5176
16	6:41	J.C.	193	114	2	1	0	0	1292	38	0	9	0	0	8	95248	2396	3344	161853	1662	4058
17	7:16	J.C.	194	114	2	1	0	0	1299	38	0	7	0	0	9	98013	2765	3475	163530	1677	4442
18	7:12	J.C.	195	114	2	1	0	0	1307	38	0	8	0	0	12	10132	3119	3314	165785	2255	5374
19	7:08	J.C.	196	115	2	1	0	0	1317	38	0	10	0	0	11	104293	3161	3353	168188	2403	5564
20	6:47	J.C.	197	116	2	1	0	0	1326	38	0	9	0	0	11	107698	3465	3232	170380	2192	5597
21	7:07	J.C.	198	116	2	1	0	0	1336	38	0	10	0	0	12	110918	3220	3347	172211	1831	5051
22	8:24	J.C.	199	117	2	1	0	0	1346	38	0	10	0	0	6	112478	1560	3219	173548	1337	2897
23	8:23	J.C.	200	117	2	1	0	0	1351	38	0	5	0	0	4	113691	1213	3304	174891	1343	2556
24	7:12	J.C.	200	117	2	0	0	0	1355	38	0	4	0	0	4	114963	1272	3097	176102	1211	2485
25	7:08	J.C.	201	117	2	1	0	0	1358	38	0	3	0	0	4	117064	2101	3269	177250	1148	3249
26	7:08	J.C.	202	117	2	1	0	0	1365	38	0	7	0	0	5	118724	1660	3345	178384	1134	2794
27	7:15	J.C.	203	117	2	1	0	0	1370	38	0	5	0	0	7	120842	2118	3329	179664	1280	3398
28	7:18	J.C.	203	117	2	0	0	0	1376	38	0	6	0	0	8	123212	2370	3297	181048	1384	3754
29	8:07	J.C.	204	117	2	1	0	0	1384	38	0	6	0	0	7	125420	2208	3310	182231	1183	3391
30	7:50	J.C.	204	117	2	1	0	0	1390	38	0	6	0	0	8	127685	2265	3270	183254	1023	3208
31	7:17	J.C.	205	117	2	0	0	0	1397	38	0	7	0	0	6	129660	1775	3352	184328	1074	3049