

State of Oregon Drinking Water Services
Monthly Disinfection Report for Ground Water Systems

System Name City of Boardman PWS ID# 41 00130
 Month/Year 11/22 Entry Point: EP-A for Ranney Wells Required Minimum Residual 0.2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	7:09	col 1 & 2	0.89	
2	7:15	col 1 & 2	0.84	
3	7:18	col 1 & 2	0.82	
4	7:09	col 1 & 2	0.74	
5	6:16	col 1 & 2	0.76	
6		col 1 & 2	0.76	
7	7:22	col 1 & 2	0.76	
8	7:03	col 1 & 2	0.73	
9	7:05	col 1 & 2	0.72	
10	7:06	col 1 & 2	0.64	
11	6:57	col #1 & 2	0.58	
12	7:25	col 1 & 2	0.60	
13	6:08	col 1 & 2	0.59	
14	7:07	col 1 & 2	0.57	
15	7:06	col 1 & 2	0.92	
16	7:08	col 1 & 2	0.68	
17	7:05	col 1 & 2	0.77	
18	7:06	col 1 & 2	0.74	
19	7:20	col 1 & 2	0.76	
20	7:22	col 1 & 2	0.82	
21	7:00	col 1 & 2	0.84	
22	7:03	col 1 & 2	0.82	
23	7:00	col 1 & 2	0.82	
24	8/6	col 1 & 2	0.76	
25	8/9	col 1 & 2	0.78	
26	8:40	col 1 & 2	0.77	
27	8:29	col. 1 and 2	0.78	
28	7:30	col. 1 and 2	0.76	
29	7:10	col. 1 and 2	0.37	
30	7:02	col. 1 and 2	0.61	
31				

Was the chlorine residual ever less than the required minimum residual of 0.2 mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ Hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer
 If yes, did you monitor every four hours until the residual returned to 0.2 mg/L as required?
 Yes No
 Attach those results and submit them with this form.

GWS Serving More Than 3,300
 Did continuous monitoring equipment fail at any time this reporting month? Yes No
 If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required?
 Yes No
 Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed: _____
 Date it was returned to service: _____

Printed Name: Kevin Kennedy _____ Title: PWD _____
 Signature: _____ Phone #: (541) 481-9252 _____
 Date: _____/_____/_____

Operator Certification
 #: D/T-6106

Ranney (Raw) Stations Log

For the Month of: November 2022

Date	Time	Initials	Collector #1						Collector #2						Total Hours	Flow Meters				Daily Coll. Flows				
			#1	#2	#3	#1	#2	#3	#1	#2	#1	#2	GPM	Total		Daily	GPM	Total	Daily					
7:14		J.C.	205	117	2	x			1403	38		x			7	x	5716	129660	1940	x	3275	185482	1154	3094
7:18		J.C.	206	117	2	0	0	0	1409	38	6	0	0	5	5	5811	131600	1940		3275	185482	1154	2834	
7:21		J.C.	207	117	2	0	0	0	1414	38	5	0	0	5	5	5811	133066	1940		3275	186850	1368	2873	
7:12		J.C.	208	117	2	1	0	0	1418	38	4	0	0	5	5	5699	134502	1936		3267	188287	1437	2752	
7:12		J.C.	208	117	2	0	0	0	1422	38	4	0	0	5	5	5714	135847	1945		3336	189698	1411	4194	
7:14		N.A.	209	117	2	1	0	0	1428	38	6	0	0	6	6	5714	137459	1812		3333	190859	1161	3136	
7:14		N.A.	210	117	2	1	0	0	1432	38	5	0	0	6	6	5555	139077	1428		3331	192541	1702	2822	
7:12		N.A.	210	117	2	0	0	0	1437	38	5	0	0	5	5	5716	140711	1634		3231	193749	1188	2890	
7:10		J.C.	211	117	2	1	0	0	1442	38	5	0	0	5	5	5721	142368	1657		3332	194982	1233	2939	
7:08		S	212	117	2	1	0	0	1446	38	4	0	0	5	5	5719	143441	1073		3492	196848	1866	4432	
7:29		J.C.	213	117	2	1	0	0	1450	38	4	0	0	5	5	5816	144781	1346		3276	199946	3692	2626	
6:11		J.C.	214	117	2	1	0	0	1453	38	3	0	0	5	5	5812	145872	1691		3322	201425	1535	2672	
7:12		J.C.	215	117	2	1	0	0	1457	38	4	0	0	5	5	5709	146965	1693		3229	203054	1579	2652	
7:12		J.C.	216	117	2	1	0	0	1459	38	2	0	0	5	5	5753	147935	965		3296	204741	1687	2715	
7:08		J.C.	216	117	2	0	0	0	1463	38	4	0	0	5	5	5699	149014	1084		3316	206372	1631	2745	
7:14		J.C.	217	117	2	0	0	0	1468	38	3	0	0	3	3	5721	150028	1014		3117	208103	1731	2745	
7:05		J.C.	217	117	2	1	0	0	1469	38	1	0	0	2	2	5699	151087	1059		3367	209750	1647	2761	
7:05		J.C.	218	117	2	0	0	0	1469	38	0	0	0	1	1	5717	152099	1612		3369	211349	1549	2611	
7:05		J.C.	218	117	2	0	0	0	1472	38	3	0	0	3	3	5789	153112	1013		3262	212921	1572	2585	
7:05		J.C.	220	117	2	0	0	0	1475	38	3	0	0	5	5	5721	154135	1023		3254	214523	1602	2625	
7:05		J.C.	220	117	2	0	0	0	1478	38	3	0	0	3	3	5498	155170	1035		3319	216060	1537	2572	
7:05		J.C.	221	117	2	0	0	0	1485	38	2	0	0	8	8	5821	156166	996		3318	217542	1532	2528	
7:05		J.C.	222	117	2	1	0	0	1488	38	3	0	0	4	4	5866	157197	1631		3289	219237	1645	2676	
7:05		J.C.	223	117	2	1	0	0	1491	38	3	0	0	4	4	5866	158190	993		3233	220856	1619	2612	
7:05		J.C.	224	117	2	0	0	0	1494	38	0	0	0	4	4	5721	159284	1094		3288	222546	1690	2784	
7:05		J.C.	225	117	2	0	0	0	1497	38	0	0	0	3	3	5721	160250	966		3200	223993	1447	2413	
7:05		J.C.	226	117	2	1	0	0	1497	38	3	0	0	3	3	5721	161228	978		3349	225383	1390	2368	
7:05		J.C.	227	117	2	1	0	0	1500	38	3	0	0	3	3	5780	162204	976		3320	226905	1522	2498	
7:05		J.C.	227	117	2	0	0	0	1506	38	3	0	0	4	4	5690	163155	951		3278	228248	1343	2294	
7:05		J.C.	228	117	2	0	0	0	1506	38	3	0	0	3	3	5721	164139	984		3236	229167	1519	2503	
7:05		J.C.	228	117	2	1	0	0	1502	38	3	0	0	4	4	5738	165152	1013		3298	231464	1697	2746	