

State of Oregon Drinking Water Services
Monthly Disinfection Report for Ground Water Systems

System Name City of Boardman PWS ID# 41 00130
 Month/Year 03/23 Entry Point: EP-A for Ranney Wells Required Minimum Residual 0.2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	7:28	Col 1#2	0.65	
2	7:20	Col 1#2	0.60	
3	7:11	Col 1#2	0.64	
4	7:13	Col 1#2	0.55	
5	7:59	Col 1#2	0.57	
6	7:08	Col 1#2	0.52	
7	7:09	Col 1#2	0.63	
8	7:18	Col 1#2	0.55	
9	7:10	Col 1#2	0.55	
10	7:00	Col 1#2	0.54	
11	7:33	Col 1#2	0.56	
12	7:53	Col 1#2	0.61	
13	7:26	Col 1#2	0.60	
14	7:12	Col 1#2	0.61	
15	7:00	Col 1#2	0.66 0.62	
16	7:03	Col 1#2	0.63	
17	7:05	Col 1#2	0.62	
18	7:43	Col 1#2	0.51	
19	7:59	Col 1#2	0.48	
20	7:17	Col 1#2	0.49	
21	7:04	Col 1#2	0.46	
22	7:10	Col 1#2	0.49	
23	7:11	Col 1#2	0.60	
24	7:04	Col 1#2	0.72	
25	7:17	Col # 1#2	0.79	
26	7:40	Col # 1#2	0.78	
27	7:05	Col # 1#2	0.82	
28	7:10	Col 1#2	0.77	
29	7:13	Col 1#2	0.71	
30	7:10	Col 1#2	0.62	
31	7:17	Col 1#9	0.58	

Was the chlorine residual ever less than the required minimum residual of 0.2 mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ Hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer
 If yes, did you monitor every four hours until the residual returned to 0.2 mg/L as required?
 Yes No
 Attach those results and submit them with this form.

GWS Serving More Than 3,300
 Did continuous monitoring equipment fail at any time this reporting month? Yes No
 If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required?
 Yes No
 Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed: _____
 Date it was returned to service: _____

Printed Name: Kevin Kennedy Title: PWD
 Signature: [Signature] Phone #: (541) 481-9252
 Date: 04/13/2023

Operator Certification
 #: D/T-6106

Ramney (Raw) Stations Log

For the Month of: March

Date	Time	Initials	Collector #1			Collector #2			Total Hours	Flow Meters																		
			#1	#2	#3	#1	#2	#3		Collector #2		Collector #1																
										Daily	Total	Daily	Total															
1	7:06	JE	40	0	0	x	x	x	409	0	0	x	x	218	0	0	11	0	0	12	574	231921	1668	3221	36964	1313	2981	
2	7:23	JE	42	0	0	1	0	0	223	0	0	5	0	0	0	0	0	5	0	0	6	586	233598	1472	3196	363106	1202	2879
3	7:15	JE	42	0	0	0	0	0	227	0	0	4	0	0	0	0	0	4	0	0	4	5781	274940	1342	3187	364432	1366	2708
4	7:14	9	43	0	0	1	0	0	231	0	0	4	0	0	0	0	0	5	0	0	5	5762	274630	1290	3181	365852	1380	2770
5	8:03	9	44	0	0	1	0	0	236	0	0	5	0	0	0	0	0	6	0	0	6	5772	27784	1654	3186	367211	1359	2770
6	7:11	J.C.	44	0	0	0	0	0	241	0	0	5	0	0	0	0	0	5	0	0	5	5768	279571	1787	3214	368281	1670	2857
7	7:12	J.C.	45	0	0	1	0	0	246	0	0	5	0	0	0	0	0	6	0	0	6	5796	281062	1491	3177	369587	1306	2797
8	7:21	N.C.	46	0	0	1	0	0	251	0	0	5	0	0	0	0	0	6	0	0	6	5708	282711	1649	3190	370899	1312	2761
9	7:13	J.C.	46	0	0	0	0	0	256	0	0	5	0	0	0	0	0	6	0	0	6	5787	284278	1567	3212	372101	1202	2769
10	7:08	JE	46	0	0	0	0	0	261	0	0	5	0	0	0	0	0	5	0	0	5	5791	285767	1489	3214	373357	1256	2745
11	7:36	J.C.	47	0	0	0	0	0	266	0	0	5	0	0	0	0	0	6	0	0	6	5803	287594	1827	3196	374519	1162	2745
12	7:55	J.C.	48	0	0	1	0	0	272	0	0	6	0	0	0	0	0	7	0	0	7	5803	287594	1827	3196	374519	1162	2745
13	7:28	J.C.	49	0	0	1	0	0	277	0	0	5	0	0	0	0	0	7	0	0	7	5764	289386	1792	3223	375662	1143	2935
14	7:15	J.C.	49	0	0	0	0	0	282	0	0	5	0	0	0	0	0	6	0	0	6	5777	291806	1820	3185	376809	1147	2967
15	7:25	JE	50	0	0	1	0	0	287	0	0	5	0	0	0	0	0	6	0	0	6	5795	292718	1512	3219	378632	1223	2735
16	7:09	J.C.	51	0	0	1	0	0	291	0	0	4	0	0	0	0	0	5	0	0	5	5781	294767	1649	3211	379319	1287	2936
17	7:25	J.C.	51	0	0	0	0	0	295	0	0	4	0	0	0	0	0	5	0	0	5	5811	295864	1437	3195	380688	1369	2806
18	7:46	J.C.	52	0	0	1	0	0	299	0	0	4	0	0	0	0	0	4	0	0	4	5799	297697	1293	3233	382184	1496	2789
19	8:02	J.C.	53	0	0	1	0	0	302	0	0	3	0	0	0	0	0	5	0	0	5	5767	298375	1278	3194	383422	1242	2528
20	7:13	J.C.	53	0	0	0	0	0	304	0	0	2	0	0	0	0	0	4	0	0	4	5803	299191	816	3216	384482	1656	1822
21	7:11	JE	54	0	0	0	0	0	307	0	0	3	0	0	0	0	0	4	0	0	4	5756	300011	820	3187	385499	1017	1837
22	7:13	N.C.	54	0	0	0	0	0	309	0	0	2	0	0	0	0	0	4	0	0	4	5774	300826	815	3221	386691	1200	1837
23	7:12	J.C.	55	0	0	0	0	0	312	0	0	3	0	0	0	0	0	4	0	0	4	5816	301635	809	3219	387780	1089	1892
24	7:13	JE	55	0	0	0	0	0	314	0	0	2	0	0	0	0	0	2	0	0	2	5793	302517	882	3213	388962	1182	2064
25	7:23	9	56	0	0	0	0	0	317	0	0	3	0	0	0	0	0	4	0	0	4	5821	303367	850	3229	390012	1050	1900
26	7:09	9	57	0	0	0	0	0	320	0	0	3	0	0	0	0	0	4	0	0	4	5811	304186	819	3384	39187	1175	1994
27	7:09	N.A.	57	0	0	0	0	0	322	0	0	3	0	0	0	0	0	4	0	0	4	5711	305025	839	3196	392431	1244	2083
28	7:13	J.C.	58	0	0	0	0	0	322	0	0	2	0	0	0	0	0	4	0	0	4	5625	305857	832	3222	393489	1058	1870
29	7:17	N.C.	58	0	0	0	0	0	325	0	0	3	0	0	0	0	0	4	0	0	4	5658	306472	915	3215	394490	1301	2216
30	7:13	J.C.	59	0	0	0	0	0	328	0	0	3	0	0	0	0	0	3	0	0	3	5802	307754	982	3311	396684	1294	2276
31	7:21	N.A.	60	0	0	0	0	0	331	0	0	3	0	0	0	0	0	4	0	0	4	5787	308718	964	3281	397364	1280	2294
									335	0	0	4	0	0	0	0	0	5	0	0	5	5820	310254	1536	3247	398685	1321	2857