

State of Oregon Drinking Water Services
Monthly Disinfection Report for Ground Water Systems

System Name City of Boardman PWS ID# 41 00130
 Month/Year 04 123 Entry Point: EP-A for Ranney Wells Required Minimum Residual 0.2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	8:20	Col 1 N 2	0.53	
2	8:22	Col 1 N 2	0.57	
3	7:03	Col 1 N 2	0.58	
4	7:20	Col N 2	0.58	
5	7:12	Col 1 N 2	0.56	
6	7:08	col 1 N 2	0.51	
7	7:18	col 1 N 2	0.67	
8	7:45	col 1 N 2	0.73	
9	6:45	col 1 E 2	0.73	
10	7:13	col 1 N 2	0.74	
11	7:07	col 1 N 2	0.74	
12	7:10	col 1 N 2	0.71	
13	7:13	col 1 N 2	0.70	
14	7:08	col 1 N 2	0.71	
15	6:28	col 1 N 2	0.70	
16	8:43	col 1 N 2	0.70	
17	7:08	col 1 E 2	0.81	
18	7:09	col 1 N 2	0.70	
19	7:00	col 1 E 2	0.88	
20	7:09	col 1 E 2	0.85	
21	7:16	col 1 N 2	0.83	
22	7:55	col 1 N 2	0.85	
23	8:20	col 1 N 2	0.84	
24	7:00	col 7 N 2	0.84	
25	7:15	col 1 N 2	0.82	
26	5:56	col 1 N 2	0.98	
27	7:07	col 1 N 2	1.00	
28	7:10	col 1 N 2	1.00	
29	8:63	col # 1 N 2	0.76	
30	8:21	col # 1 N 2	0.75	
31				

Was the chlorine residual ever less than the required minimum residual of 0.2 mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ Hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer
 If yes, did you monitor every four hours until the residual returned to 0.2 mg/L as required?
 Yes No
 Attach those results and submit them with this form.

GWS Serving More Than 3,300
 Did continuous monitoring equipment fail at any time this reporting month? Yes No
 Date continuous monitoring equipment failed: _____
 If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required?
 Yes No
 Date it was returned to service: _____
 Attach grab sample results and submit them with this form.

Printed Name: Kevin Kennedy Title: PWD
 Signature: [Signature] Phone #: (541) 481-9252
 Date: 5/1/2023

Operator Certification
 #: D/T-6106

Ranney (Raw) Stations Log

For the Month of: March

Date	Time	Initials	Collector #1						Collector #2						Total Pump Hrs.	Total Hours	Flow Meters						Daily Coll. Flows		
			Total Pump Hours			Daily Hours			Total Pump Hrs.			Daily Hrs.					GPM	Total	Daily	GPM	Total	Daily			
			#1	#2	#3	#1	#2	#3	#1	#2	#3	#1	#2	#3											
1	7:06	JL	40	0	0	0	x	0	0	0	409	0	0	0	x	0	0	0	5794	271921	1668	3221	361904	1313	2981
2	7:23	JL	42	0	0	0	1	0	0	223	0	0	5	0	0	0	0	0	5816	273598	1672	3196	363106	1262	2859
3	7:13	JL	42	0	0	0	0	0	0	227	0	0	4	0	0	0	0	0	5781	274940	1342	3187	364472	1366	2708
4	7:14	9	43	0	0	0	1	0	0	231	0	0	4	0	0	0	0	0	5762	276630	1290	3181	365852	1380	2670
5	8:03	9	44	0	0	0	1	0	0	236	0	0	5	0	0	0	0	0	5772	277884	1654	3184	367211	1359	3013
6	7:11	JL	44	0	0	0	0	0	0	241	0	0	5	0	0	0	0	0	5768	279571	1787	3214	368281	1070	2857
7	7:12	JL	45	0	0	0	1	0	0	246	0	0	5	0	0	0	0	0	5796	281662	1491	3177	369587	1306	2797
8	7:21	N/A	46	0	0	0	1	0	0	251	0	0	5	0	0	0	0	0	5708	282711	1649	3190	370899	1312	2961
9	7:13	JL	46	0	0	0	0	0	0	256	0	0	5	0	0	0	0	0	5787	284278	1567	3212	372101	1202	2769
10	7:08	JL	46	0	0	0	0	0	0	261	0	0	5	0	0	0	0	0	5791	285767	1489	3219	373357	1256	2745
11	7:36	JL	47	0	0	0	1	0	0	266	0	0	5	0	0	0	0	0	5803	287594	1827	3196	374519	1162	2489
12	7:35	JL	48	0	0	0	1	0	0	272	0	0	6	0	0	0	0	0	5764	289386	1792	3223	375662	1143	2935
13	7:28	JL	49	0	0	0	1	0	0	277	0	0	5	0	0	0	0	0	5777	291306	1820	3185	376809	1147	2967
14	7:15	JL	49	0	0	0	0	0	0	282	0	0	5	0	0	0	0	0	5795	292718	1512	3219	378032	1223	2735
15	7:05	JL	50	0	0	0	1	0	0	287	0	0	5	0	0	0	0	0	5781	294367	1649	3211	379319	1287	2936
16	7:09	JL	51	0	0	0	1	0	0	291	0	0	4	0	0	0	0	0	5811	295864	1437	3195	380688	1369	2806
17	7:25	JL	51	0	0	0	0	0	0	295	0	0	4	0	0	0	0	0	5799	297697	1293	3233	382184	1496	2789
18	7:46	JL	52	0	0	0	1	0	0	299	0	0	4	0	0	0	0	0	5767	298375	1278	3199	383426	1242	2528
19	8:02	JL	53	0	0	0	1	0	0	302	0	0	3	0	0	0	0	0	5803	299491	816	3216	384482	1056	1822
20	7:13	JL	53	0	0	0	0	0	0	307	0	0	2	0	0	0	0	0	5756	300011	820	3187	385494	1017	1837
21	7:11	JL	54	0	0	0	1	0	0	309	0	0	3	0	0	0	0	0	5774	300826	815	3221	386691	1200	1837
22	7:13	JL	54	0	0	0	0	0	0	309	0	0	2	0	0	0	0	0	5816	301635	809	3219	387780	1089	1892
23	7:12	JL	55	0	0	0	0	0	0	312	0	0	3	0	0	0	0	0	5793	302517	882	3213	388962	1182	2064
24	7:13	JL	55	0	0	0	0	0	0	314	0	0	2	0	0	0	0	0	5821	303367	850	3229	390012	1050	1900
25	7:03	9	54	0	0	0	1	0	0	317	0	0	3	0	0	0	0	0	5611	304186	819	3384	391187	1175	1944
26	7:00	9	57	0	0	0	1	0	0	320	0	0	3	0	0	0	0	0	5711	305025	839	3194	392493	1274	2083
27	7:07	N/A	57	0	0	0	0	0	0	322	0	0	2	0	0	0	0	0	5795	305857	832	3322	393499	1058	1870
28	7:13	JL	58	0	0	0	0	0	0	325	0	0	3	0	0	0	0	0	5658	306772	915	3215	394790	1301	2211
29	7:17	N/A	58	0	0	0	0	0	0	328	0	0	3	0	0	0	0	0	5802	307754	982	3311	396084	1294	2276
30	7:13	JL	59	0	0	0	1	0	0	331	0	0	3	0	0	0	0	0	5787	308718	964	3281	397364	1280	2244
31	7:21	N/A	60	0	0	0	1	0	0	335	0	0	4	0	0	0	0	0	5820	310254	1536	3247	398685	1321	2857