

State of Oregon Drinking Water Services
Monthly Disinfection Report for Ground Water Systems

System Name _____ Boardman, City of _____

PWS ID# 41 00130

Month/Year 7/23

Entry Point: EP-A for Ranney Collector Wells

Required Minimum Residual 0.2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	7:23	col 7 & 2	0.71	
2	8:13	col 1 & 2	0.67	
3	7:05	col 1 & 2	0.63	
4	7:00	col 1 & 2	0.62	
5	8:13	col 1 & 2	0.58	
6	7:08	col 1 & 2	0.72	
7	7:05	col 1 & 2	0.79	
8	6:49	col 1 & 2	0.63	
9	7:06	col 1 & 2	0.62	
10	7:00	col 1 & 2	0.61	
11	7:01	col 1 & 2	0.68	
12	7:12	col 1 & 2	0.45	
13	7:03	col 1 & 2	0.75	
14	7:10	col 1 & 2	0.78	
15		col 1 & 2	0.92	
16		col 1 & 2	0.30	
17	7:14	col 1 & 2	0.72	
18	7:10	col 1 & 2	0.79	
19	7:08	col 1 & 2	0.70	
20	7:04	col 1 & 2	0.83	
21	7:05	col 1 & 2	0.76	
22	7:05	col 1 & 2	0.67	
23	8:15	col 1 & 2	0.68	
24	7:07	col 1 & 2	0.63	
25	7:00	col 1 & 2	0.60	
26	7:15	col 1 & 2	0.60	
27	7:01	col 1 & 2	0.67	
28	8:04	col 1 & 2	0.77	
29	7:29	col 1 & 2	0.80	
30	7:20	col 1 & 2	0.79	
31	7:02	col 1 & 2	0.76	

Was the chlorine residual ever less than the required minimum residual of 0.2 mg/L? Yes No

If yes, what was the longest time period until the required level was restored? _____ Hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer

If yes, did you monitor every four hours until the residual returned to 0.2 mg/L as required?

Yes No

Attach those results and submit them with this

GWS Serving More Than 3,300

Did continuous monitoring equipment fail at any time this reporting month?

Yes

No

If yes, were grab samples collected every four hours

Date continuous monitoring equipment failed:

____/____/____

Date it was returned to service:

____/____/____

State of Oregon Drinking Water Services
Monthly Disinfection Report for Ground Water Systems

<i>form.</i>	until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <i>Attach grab sample results and submit them with this form.</i>	
Printed Name: <i>Luis C.</i> Title: <i>Public works operator</i> Signature: <i>[Signature]</i> Phone #: (<i>541 701</i>) <i>8880</i> Date: <u> </u> / <u> </u> / <u> </u>		Operator Certification #: <u>900039</u>

Ramney (Raw) Stations Log

For the Month of: July

Date	Time	Initials	Collector #1						Collector #2						Total Hours	Collector #2			Flow Meters			Daily Co. Flows	
			Total Pump Hours			Daily Hours			Total Pump Hrs.			Daily Hrs.				GPM	Total	Daily	GPM	Total	Daily		
			#1	#2	#3	#1	#2	#3	#1	#2	#2	#2	x	x									x
18:28	N/A		163	167	0	0	0	0	0	0	0	1016	6	19	1	22	5785	536351	6385	322	628162	2949	9334
20:01	J.C.		167	168	0	0	0	0	0	0	1035	7	10	0	13	5785	542736	6385	322	628162	2949	9334	
7:13	J.C.		169	168	0	0	0	0	0	0	1054	7	9	0	10	5785	546104	3368	321	632788	4626	7994	
4:11	J.C.		170	168	0	0	0	0	0	0	1064	7	10	0	11	5785	549218	3114	321	632166	4378	7442	
8:23	J.C.		172	168	0	0	0	0	0	0	1075	7	11	0	13	5785	552429	3211	321	640326	3166	6371	
7:20	J.C.		174	169	0	0	0	0	0	0	1096	8	15	1	19	5785	556284	3855	324	642994	2668	6522	
7:15	J.C.		175	169	0	0	0	0	0	0	1111	8	21	0	22	5785	561198	4914	322	646756	3756	8626	
8:00	J.C.		177	170	0	0	0	0	0	0	1122	8	22	0	25	5785	568331	7133	323	649311	2561	9694	
9:12	J.C.		179	170	0	0	0	0	0	0	1137	9	15	1	18	5785	572116	3785	324	653735	4424	8209	
7:16	J.C.		181	170	0	0	0	0	0	0	1152	9	15	0	17	5785	577259	5143	315	656789	3054	8197	
7:11	J.C.		182	171	0	0	0	0	0	0	1165	9	13	0	15	5785	582261	5002	324	660050	3261	8263	
7:26	N/A		185	171	0	0	0	0	0	0	1175	10	10	1	14	5785	586703	4442	322	663384	3334	7776	
7:10	J.C.		185	172	0	0	0	0	0	0	1191	10	16	0	17	5785	595498	5343	318	667744	4366	7812	
7:22	J.C.		188	172	0	0	0	0	0	0	1210	11	19	1	23	5785	602230	6732	316	670953	7569	12912	
7:24	J.C.		189	173	0	0	0	0	0	0	1229	11	19	0	21	5785	608597	6367	317	674428	3175	9907	
7:17	J.C.		191	173	0	0	0	0	0	0	1246	12	17	0	20	5785	614460	5863	317	677248	2920	9282	
7:14	J.C.		192	174	0	0	0	0	0	0	1263	12	17	1	19	5785	620412	5952	318	680092	3044	8907	
7:22	N/A		194	174	0	0	0	0	0	0	1280	13	17	1	20	5785	626071	5659	317	686636	3543	8453	
7:20	J.C.		196	175	0	0	0	0	0	0	1297	14	17	1	21	5785	632006	5935	321	689956	3320	9202	
7:15	J.C.		197	176	0	0	0	0	0	0	1316	14	19	0	21	5785	638599	6593	319	689956	3320	9255	
7:17	J.C.		199	176	0	0	0	0	0	0	1340	15	24	1	27	5785	646838	8239	326	692980	2974	9567	
7:20	J.C.		201	182	0	0	0	0	0	0	1352	17	14	2	24	5785	651861	4523	310	695209	2279	10518	
8:19	J.C.		203	182	0	0	0	0	0	0	1385	17	13	0	15	5785	655940	4579	319	700053	4844	7952	
7:18	J.C.		206	185	0	0	0	0	0	0	1378	17	13	0	19	5785	660107	4167	320	709696	4697	8139	
7:15	J.C.		208	185	0	0	0	0	0	0	1391	17	13	0	16	5785	664636	4529	324	714447	4751	8864	
7:12	J.C.		210	188	0	0	0	0	0	0	1404	17	13	0	17	5785	668936	4300	319	719277	4830	9280	
7:12	N/A		213	189	0	0	0	0	0	0	1417	17	13	0	17	5785	673401	4465	327	724072	4795	9185	
8:16	J.C.		215	190	0	0	0	0	0	0	1432	17	15	0	18	5785	678241	4840	314	728538	4466	9260	
8:16	J.C.		217	191	0	0	0	0	0	0	1445	17	13	0	16	5785	682731	4490	325	733367	4829	9306	
8:16	J.C.		220	192	0	0	0	0	0	0	1457	17	12	0	16	5785	686707	3976	324	737931	4564	9349	
7:13	J.C.		222	193	0	0	0	0	0	0	1469	17	12	0	15	5785	690809	4097	313	742620	4689	8548	