

State of Oregon Drinking Water Services
Monthly Disinfection Report for Ground Water Systems

System Name Boardman, City of

PWS ID# 41 00130

Month/Year 8/23

Entry Point: EP-A for Ranney Collector Wells

Required Minimum Residual 0.2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	7:00	Col 1 & 2	0.69	
2	7:20	Col 1 & 2	0.41	
3	7:21	Col 1 & 2	0.53	
4	7:18	Col 1 & 2	0.71	
5	7:31	Col 1 & 2	0.73	
6	7:41	Col 1 & 2	0.75	
7	7:21	Col 1 & 2	0.75	
8	7:13	Col 1 & 2	0.78	
9	7:20	Col 1 & N 2	0.72	
10	7:22	Col 1 & N 2	0.80	
11	7:19	Col 1 & 2	0.74	
12	7:40	Col 1 & N 2	0.80	
13	8:20	Col 1 & N 2	0.78	
14	7:23	Col 1 & 2	0.79	
15	7:20	Col 1 & 2	0.64	
16	7:22	Col 1 & 2	0.61	
17	7:16	Col 1 & 2	0.60	
18	7:20	Col 1 & 2	0.77	
19	6:43	Col 1 & 2	0.83	
20	8:08	Col 1 & 2	0.84	
21	7:09	Col 1 & 2	0.76	
22	7:20	Col 1 & 2	0.81	
23	7:03	Col 1 & 2	0.67	
24	7:05	Col 1 & 2	0.70	
25	7:07	Col 1 & 2	0.70	
26	7:48	Col 1 & 2	0.76	
27	7:17	Col 1 & 2	0.74	
28	7:06	Col 1 & 2	0.70	
29	7:11	Col 1 & 2	0.66	
30	7:07	Col 1 & 2	0.65	
31	7:07	Col 1 & 2	0.75	

Was the chlorine residual ever less than the required minimum residual of 0.2 mg/L? ☐ Yes ☒ No
 If yes, what was the longest time period until the required level was restored? _____ Hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer

If yes, did you monitor every four hours until the residual returned to 0.2 mg/L as required? ☐

Yes ☐

No ☐

Attach those results and submit them with this

Did continuous monitoring equipment fail at any time this reporting month?

☐ Yes

☒ No

If yes, were grab samples collected every four hours

GWS Serving More Than 3,300

Date continuous monitoring equipment failed:

____/____/____

Date it was returned to service:

____/____/____

State of Oregon Drinking Water Services
Monthly Disinfection Report for Ground Water Systems

form.	until the continuous monitoring equipment was returned to service as required? ☐ Yes ☒ No Attach grab sample results and submit them with this form.	
Printed Name: <u>Luis</u> Signature: <u>[Signature]</u> Date: <u>9/06</u> <u>2023</u>	Title: <u>Water Operator</u> Phone #: <u>(501) 9252</u>	Operator Certification #: <u>900039</u>

Ranney (Raw) Stations Log

For the Month of:

August

Date	Time	Initials	Collector #1										Collector #2										Total Hours	Flow Meters										Daily Coll. Flows
			Total Pump Hours					Daily Hours					Total Pump Hrs.					Daily Hrs.						Collector #1					Collector #2					
			#1	#2	#3	#1	#2	#3	#1	#2	#3	#1	#2	#3	#1	#2	#3	#1	#2	#3	#1	#2		#3	#1	#2	#3	GPM	Total	Daily	GPM	Total	Daily	
			x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x		x	x	x	x	x	x	x	x	x	x	
1	7:12	J.C.	222	193	0	3	3	0	1469	17	14	0	20	5787	695409	4605	3237	747707	5087	7692														
2	7:30	N.A.	225	196	0	2	3	0	1483	17	14	0	19	5765	700146	4737	3230	752578	4871	9608														
3	7:32	N.A.	227	199	0	2	6	0	1497	17	14	0	22	5781	704923	4777	3239	757992	5343	10120														
4	7:38	N.A.	229	205	0	3	4	0	1525	17	14	0	21	5803	709630	4707	3146	762999	5078	9785														
5	7:39	N.A.	232	209	0	2	0	0	1536	17	11	0	13	5795	713305	3675	3225	767761	4762	8437														
6	7:50	N.A.	234	209	0	3	0	0	1546	17	10	0	13	5786	716393	3088	3250	772397	4636	7724														
7	7:30	N.A.	237	209	0	2	0	0	1558	17	12	0	14	5781	720422	4029	3248	776384	3987	8016														
8	7:23	N.A.	239	209	0	2	0	0	1570	17	12	0	15	5767	724400	3978	3245	780716	4732	8316														
9	7:35	J.C.	241	210	0	2	1	0	1570	17	12	0	16	5726	728810	4410	3147	785528	4812	9222														
10	7:46	J.C.	243	211	0	2	1	0	1583	17	13	0	16	5791	733465	4655	3220	790189	4661	9316														
11	7:48	J.C.	246	213	0	3	2	0	1597	17	14	0	19	5813	737671	4206	3244	795010	4821	9027														
12	7:50	J.C.	248	214	0	2	1	0	1609	17	12	0	15	5800	741712	4041	3190	799770	4760	8801														
13	8:00	J.C.	250	214	0	2	0	0	1621	17	11	0	13	5729	745453	3741	3216	804502	4732	8473														
14	7:31	N.A.	253	215	0	3	1	0	1633	17	12	0	16	5801	749375	3972	3226	809080	4578	8500														
15	7:29	N.A.	255	216	0	2	1	0	1644	17	11	0	14	5824	754515	5140	3221	814882	5802	10942														
16	7:31	J.C.	258	225	0	3	9	0	1660	17	16	0	28	5831	760091	5576	3157	820192	5310	10886														
17	7:27	N.A.	260	231	0	2	6	0	1676	17	16	0	24	5861	765378	5987	3239	826077	5885	11172														
18	7:32	N.A.	262	241	0	2	10	0	1692	17	16	0	28	5809	770119	4741	3221	831014	4937	9678														
19	7:39	N.A.	265	244	0	3	3	0	1706	17	14	0	20	5810	774261	4542	3207	835581	4567	9109														
20	8:02	S	267	245	0	2	1	0	1720	17	14	0	17	5814	778548	3887	3210	840285	5104	8314														
21	7:26	J.C.	270	245	0	3	0	0	1731	17	11	0	14	5797	782057	3509	3232	845046	4361	7878														
22	7:30	J.C.	272	246	0	2	1	0	1742	17	11	0	15	5807	786033	3976	3226	849707	4661	8637														
23	7:14	J.C.	274	247	0	2	1	0	1754	17	12	0	14	5808	789814	3781	3184	854311	4604	8385														
24	7:17	J.C.	277	247	0	3	0	0	1765	17	11	0	13	5798	793655	3841	3210	858999	4688	8529														
25	7:17	J.C.	279	247	0	2	0	0	1776	17	11	0	17	5814	797735	4080	3186	863786	4787	8867														
26	8:00	J.C.	281	249	0	2	2	0	1789	17	13	0	14	5823	801237	3502	3229	868591	4805	8307														
27	7:24	J.C.	284	250	0	3	1	0	1799	17	16	0	13	5786	804873	3636	3199	873096	4505	8141														
28	7:16	J.C.	286	250	0	2	6	0	1816	17	11	0	16	5800	808966	4093	3236	877731	4635	8728														
29	7:10	J.C.	289	251	0	3	1	0	1828	17	12	0	18	5806	813545	4579	3171	882551	4820	9399														
30	7:21	J.C.	291	253	0	2	2	0	1836	17	14	0	16	5821	818473	4928	3221	885820	3269	8147														
31	7:16	J.C.	293	253	0	2	0	0	1850	17	14	0	13	5780	822109	3636	3245	890298	4878	8114														