

State of Oregon Drinking Water Services
Monthly Disinfection Report for Ground Water Systems

System Name Boardman, City of PWS ID# 41 00130
Month/Year 11 / 2023 Entry Point: EP-A for Ranney Collector Wells Required Minimum Residual 0.2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	7:05	Col 1 & 2	0.67	
2	7:10	Col 1 & 2	0.64	
3	7:21	Col 1 & 2	0.76	
4	8:00	Col 1 - N 2	0.87	
5	7:00	Col 1 N 2	0.73	
6	7:00	Col 1 & 2	0.73	
7	7:05	Col 1 & 2	0.70	
8	7:06	Col 1 & 2	0.65	
9	7:00	Col 1 & 2	0.83	
10	8:10	Col 1 N 2	0.77	
11	8:05	Col # 1 & 2	0.80	
12	8:05	Col # 1 & 2	0.85	
13	7:40	Col 1 & 2	0.86	
14	7:00	Col 1 & 2	0.88	
15	7:03	Col 1 & 2	0.95	
16	7:00	Col 1 & 2	0.85	
17	7:15	Col 1 & 2	0.81	
18	6:29	Col 1 & 2	0.78	
19	7:16	Col 1 & 2	0.67	
20	7:00	Col 1 & 2	0.63	
21	7:00	Col 1 & 2	0.84	
22	7:30	Col 1 & 2	0.85	
23	6:41	Col 1 & 2	0.91	
24	7:40	Col 1 & 2	0.76	
25	7:30	Col 1 & 2	0.75	
26	7:40	Col 1 & 2	0.73	
27	7:00	Col 1 & 2	0.73	
28	7:00	Col 1 & 2	0.50	
29	7:00	Col 1 & 2	0.51	
30	7:01	Col 1 & 2	0.72	
31				

Was the chlorine residual ever less than the required minimum residual of 0.2 mg/L? ☐ Yes ☒ No

If yes, what was the longest time period until the required level was restored? _____ Hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer

If yes, did you monitor every four hours until the residual returned to 0.2 mg/L as required? ☐ Yes ☒ No

Attach those results and submit them with this form.

GWS Serving More Than 3,300

Did continuous monitoring equipment fail at any time this reporting month? ☐ Yes ☒ No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? ☐ Yes ☒ No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed: _____

Date it was returned to service: _____

Printed Name: Luis Camargo

Signature: _____

Date: 12 / 6 / 2023

Title: Water operator

Phone #: (541) 481-9252

Operator Certification #: 900039

For the Month of: November

November

Date	Time	Initials	Collector #1						Collector #2						Flow Meters						Daily Coll. Flows
			Total Pump Hours			Daily Hours			Total Pump Hrs.			Daily Hrs.			Collector #2			Collector #1			
			#1	#2	#3	#1	#2	#3	#1	#2	#3	#1	#2	#3	GPM	Total	Daily	GPM	Total	Daily	
1	7:10	JP	387	256	0	1	0	0	2395	17		6	0	0	5710	1274	2191	3290	72795	1233	3424
2	7:10	JP	388	256	0	1	0	0	2401	17	8	0	0	0	5726	3630	2356	3285	74147	1352	3708
3	7:10	JP	389	256	0	0	0	0	2409	17	8	0	0	0	5701	5809	2179	3291	75473	1326	3505
4	7:10	JP	390	256	0	1	0	0	2415	17	5	0	0	0	5695	7208	1399	3270	76944	1507	2900
5	7:20	JP	391	256	0	1	0	0	2420	17	4	0	0	0	5715	8590	1382	3301	78370	1756	3138
6	7:10	JP	391	256	0	0	0	0	2431	17	7	0	0	0	5698	10956	2366	3310	79606	1236	3602
7	7:10	JP	391	256	0	0	0	0	2439	17	8	0	0	0	5690	13395	2439	3291	80939	1333	2772
8	7:15	J.C	393	256	0	2	0	0	2446	17	7	0	0	0	5675	15826	2431	3287	82180	1241	3672
9	7:10	JP	393	256	0	0	0	0	2452	17	6	0	0	0	5675	17826	2000	3290	83456	1276	3276
10	8:20	JP	394	256	0	0	0	0	2460	17	8	0	0	0	5735	20295	2469	3336	84868	1408	3877
11	8:09	JP	395	256	0	1	0	0	2467	17	7	0	0	0	5613	22772	2457	3317	86339	1471	3928
12	8:12	JP	395	256	0	0	0	0	2475	17	8	0	0	0	5716	25157	3385	3266	87463	1124	4509
13	7:10	JP	396	256	0	1	0	0	2482	17	7	0	0	0	5715	27510	2353	3270	88762	1299	3852
14	7:10	JP	396	256	0	0	0	0	2491	17	9	0	0	0	5695	30417	2907	3310	90189	1427	4334
15	7:12	J.C	398	256	0	2	0	0	2502	17	11	0	0	0	5795	34314	3897	3297	91887	1698	5595
16	7:10	JP	399	256	0	1	0	0	2510	17	8	0	0	0	5690	36845	2881	3300	94534	2647	5178
17	7:25	N.A.	400	256	0	1	0	0	2520	17	10	0	0	0	5707	40005	3160	3291	96465	2135	5291
18	6:35	J.C	401	256	0	1	0	0	2527	17	9	0	0	0	5673	43248	3243	3317	98166	1701	4944
19	7:21	J.C	401	256	0	0	0	0	2535	17	6	0	0	0	5696	44936	1688	3285	99626	1960	5148
20	7:10	JP	402	256	0	1	0	0	2542	17	7	0	0	0	5690	47346	2410	3260	100814	1188	3598
21	7:10	JP	403	256	0	1	0	0	2547	17	5	0	0	0	5710	49083	1737	3285	103150	2336	4073
22	7:44	N.A.	404	256	0	1	0	0	2554	17	7	0	0	0	5711	51353	2270	3190	104735	1585	3855
23	6:46	J.C	405	256	0	1	0	0	2558	17	4	0	0	0	5687	52639	1286	3306	106114	1379	2665
24	7:44	J.C	406	256	0	1	0	0	2561	17	3	0	0	0	5701	53653	1014	3281	107606	1492	2506
25	7:39	N.A.	406	256	0	0	0	0	2564	17	3	0	0	0	5458	54635	982	3290	108975	1389	2371
26	7:50	N.A.	407	256	0	1	0	0	2567	17	3	0	0	0	5630	55557	922	3320	110429	1434	2356
27	7:16	JP	408	256	0	1	0	0	2570	17	3	0	0	0	5420	56538	981	3315	111770	1341	7322
28	7:10	JP	408	256	0	0	0	0	2573	17	3	0	0	0	5225	57423	935	3291	113253	1463	2308
29	7:10	JP	409	256	0	1	0	0	2576	17	3	0	0	0	5200	58439	966	3319	114669	1496	2442
30	7:11	J.C	410	256	0	1	0	0	2579	17	3	0	0	0	5734	59395	956	3299	116143	1474	2430
31																					