

State of Oregon Drinking Water Services
Monthly Disinfection Report for Ground Water Systems

System Name Boardman, City of PWS ID# 41 00130
Month/Year 12 /2023 Entry Point: EP-A for Ranney Collector Wells Required Minimum Residual 0.2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	7:00	Col 1 & 2	0.74	
2	7:00	Col 1 & 2	0.77	
3	8:00	Col 1 & 2	0.76	
4	7:00	Col 1 & 2	0.75	
5	7:23	Col 1 & 2	0.82	
6	7:02	Col 1 & 2	0.83	
7	7:00	Col 1 & 2	0.81	
8	7:00	Col 1 & 2	0.79	
9	7:40	Col 1 & 2	0.79	
10	8:25	Col 1 & 2	0.77	
11	7:00	Col 1 & 2	0.79	
12	7:04	Col 1 & 2	0.68	
13	7:00	Col 1 & 2	0.69	
14	7:01	Col 1 & 2	0.66	
15	7:00	Col 1 & 2	0.70	
16	8:00	Col 1 & 2	0.67	
17	8:01	Col 1 & 2	0.61	
18	7:00	Col 1 & 2	0.69	
19	7:10	Col 1 & 2	0.66	
20	7:16	Col 1 & 2	0.67	
21	7:35	Col 1 & 2	0.75	
22	7:45	Col 1 & 2	0.70	
23	7:47	Col 1 & 2	0.72	
24	8:00	Col 1 & 2	0.65	
25	6:45	Col 1 & 2	0.69	
26	6:50	Col 1 & 2	0.67	
27	7:20	Col 1 & 2	0.66	
28	7:24	Col 1 & 2	0.69	
29	7:00	Col 1 & 2	0.73	
30	7:31	Col 1 & 2	0.70	
31	7:45	Col 1 & 2	0.73	

Was the chlorine residual ever less than the required minimum residual of 0.2 mg/L? ☐ Yes ☒ No

If yes, what was the longest time period until the required level was restored? _____ Hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer If yes, did you monitor every four hours until the residual returned to 0.2 mg/L as required? ☐ Yes ☐ No Attach those results and submit them with this form.	GWS Serving More Than 3,300 Did continuous monitoring equipment fail at any time this reporting month? ☐ Yes ☒ No If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? ☐ Yes ☐ No Attach grab sample results and submit them with this form.	Date continuous monitoring equipment failed: _____/_____/_____ Date it was returned to service: _____/_____/_____
--	---	---

Printed Name: <u>Luis Campos</u> Signature: _____ Date: <u>1 / 14 / 2024</u>	Title: <u>Water Operator</u> Phone #: <u>(541) 481-9252</u>	Operator Certification #: <u>900039</u>
--	--	---

Ranney (Raw) Stations Log

For the Month of: December

Collector #1										Collector #2										Flow Meters									
Total Pump Hours					Daily Hours					Total Pump Hrs.					Daily Hrs.					Collector #2					Collector #1				
Date	Time	Initials	#1	#2	#3	#1	#2	#3	#1	#2	#3	#1	#2	#3	#1	#2	#3	GPM	Total	Daily	GPM	Total	Daily	Daily Coll. Flows					
Last Reading ==>																													
1	7:20	JP	410	256	0	x	x	x	2579	17	3	x	x	x	4	3100	60425	1030	3100	117 467	1324	2352							
2	7:29	JP	411	256	0	0	0	0	2582	17	3	0	0	0	3	5790	61425	1020	3220	118 964	1497	2497							
3	8:10	JP	412	256	0	1	0	0	2588	17	3	0	0	0	4	5801	62462	1037	3196	120 634	1670	2707							
4	9:10	JP	413	256	0	1	0	0	2591	17	3	0	0	0	4	5580	63438	926	3215	122 182	1548	2524							
5	7:29	JP	414	256	0	1	0	0	2594	17	3	0	0	0	4	5612	64420	982	3169	123 689	1507	2489							
6	7:12	JP	414	256	0	0	0	0	2597	17	3	0	0	0	3	5727	65458	1038	3187	125 148	1459	2497							
7	7:10	JP	415	256	0	0	0	0	2600	17	3	0	0	0	3	5686	66439	981	3150	126 636	1488	2469							
8	7:10	JP	416	256	0	1	0	0	2603	17	3	0	0	0	4	5300	67408	969	3100	128 195	1559	2525							
9	7:05	JP	417	256	0	1	0	0	2606	17	3	0	0	0	4	5447	68306	898	3216	132 530	1421	2319							
10	8:11	JP	417	256	0	0	0	0	2609	17	3	0	0	0	3	5323	69423	1117	3176	131 073	1457	2544							
11	7:10	JP	418	256	0	1	0	0	2612	17	3	0	0	0	4	5740	70321	898	3190	132 572	1499	2397							
12	7:10	JP	419	256	0	1	0	0	2615	17	3	0	0	0	4	5461	71308	997	3185	133 985	1413	2406							
13	7:10	JP	420	256	0	1	0	0	2618	17	3	0	0	0	4	5390	72222	964	3160	135 423	1438	2462							
14	7:10	JP	420	256	0	0	0	0	2621	17	3	0	0	0	3	5669	73248	976	3175	136 823	1400	2376							
15	7:07	JP	421	256	0	1	0	0	2624	17	3	0	0	0	4	5652	74219	971	3192	138 338	1515	2486							
16	8:06	JP	422	256	0	1	0	0	2627	17	3	0	0	0	4	5703	75214	995	3229	139 752	1418	2418							
17	8:09	JP	423	256	0	1	0	0	2630	17	3	0	0	0	4	5759	76206	992	3188	141 182	1426	2418							
18	7:10	JP	423	256	0	0	0	0	2633	17	3	0	0	0	3	5701	77130	964	3211	142 582	1394	2304							
19	7:10	JP	424	256	0	1	0	0	2636	17	3	0	0	0	4	5630	78167	992	3135	143 930	1408	2405							
20	7:27	JP	425	256	0	1	0	0	2639	17	3	0	0	0	4	5631	79138	971	3223	145 324	1394	2365							
21	7:45	JP	425	256	0	0	0	0	2642	17	3	0	0	0	3	5671	80153	1015	3261	146 784	1466	2475							
22	7:54	JP	426	256	0	1	0	0	2645	17	3	0	0	0	4	5682	81124	971	3221	148 210	1426	2397							
23	7:54	JP	427	256	0	1	0	0	2648	17	3	0	0	0	4	5692	82170	1046	3199	149 676	1460	2506							
24	8:04	JP	428	256	0	1	0	0	2651	17	3	0	0	0	4	5823	83108	938	3306	151 074	1404	2342							
25	8:49	JP	428	256	0	0	0	0	2654	17	3	0	0	0	3	5786	83983	875	3170	152 386	1312	2182							
26	7:20	JP	429	256	0	1	0	0	2657	17	3	0	0	0	4	0	85030	1047	0	153 735	1341	2386							
27	7:10	JP	430	256	0	1	0	0	2660	17	3	0	0	0	4	5810	85963	935	3100	155 121	1436	2341							
28	7:34	JP	430	256	0	0	0	0	2663	17	3	0	0	0	3	5420	86936	973	3280	156 594	1423	2396							
29	7:10	JP	431	256	0	1	0	0	2666	17	3	0	0	0	4	5621	87912	976	3221	157 992	1398	2374							
30	7:41	JP	432	256	0	1	0	0	2669	17	3	0	0	0	4	5768	88935	1023	3281	159 355	1363	2386							
31	7:54	JP	433	256	0	1	0	0	2672	17	3	0	0	0	4	5638	89914	979	3241	160 840	1485	2418							