

**State of Oregon Drinking Water Services
Monthly Disinfection Report for Ground Water Systems**

System Name Boardman, City of PWS ID# 41 00130
 Month/Year 1 / 2024 Entry Point: EP-A for Ranney Collector Wells Required Minimum Residual 0.2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	7:45	Col 1 & 2	0.72	
2	7:40	Col 1 & 2	0.72	
3	7:00	Col 1 & 2	0.70	
4	7:00	Col 1 & 2	0.79	
5	7:00	Col 1 & 2	0.64	
6	8:30	Col 1 & 2	0.65	
7	8:35	Col 1 & 2	0.67	
8	7:00	Col 1 & 2	0.67	
9	7:00	Col 1 & 2	0.67	
10	7:05	Col 1 & 2	0.64	
11	7:13	Col 1 & 2	0.66	
12	7:10	Col 1 & 2	0.52	
13	7:50	Col # 1 & 2	0.64	
14	7:07	Col # 1 & 2	0.88	
15	7:46	Col # 1 & 2	0.65	
16	7:18	Col 1 & 2	0.68	
17	7:30	Col 1 & 2	0.73	
18	6:10	Col 1 & 2	0.73	
19	6:50	Col 1 & 2	0.83	
20	7:26	Col 1 & 2	0.86	
21	7:35	Col 1 & 2	0.73	
22	7:06	Col 1 & 2	0.73	
23	7:06	Col 1 & 2	0.86	
24	7:05	Col 1 & 2	0.79	
25	7:00	Col 1 & 2	0.73	
26	7:11	Col 1 & 2	0.68	
27	7:29	Col 1 & 2	0.69	
28	7:25	Col 1 & 2	0.79	
29	7:00	Col 1 & 2	0.49	
30	7:10	Col 1 & 2	0.49	
31	7:00	Col 1 & 2	0.59	

Was the chlorine residual ever less than the required minimum residual of 0.2 mg/L? ☐ Yes ☒ No
 If yes, what was the longest time period until the required level was restored? _____ Hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer If yes, did you monitor every four hours until the residual returned to 0.2 mg/L as required? ☐ Yes ☐ No Attach those results and submit them with this form.	GWS Serving More Than 3,300 Did continuous monitoring equipment fail at any time this reporting month? ☐ Yes ☒ No If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? ☐ Yes ☐ No Attach grab sample results and submit them with this form.	Date continuous monitoring equipment failed: ____/____/____ Date it was returned to service: ____/____/____
--	---	---

Printed Name: <u>Luis Campos</u> Signature: _____ Date: <u>2 / 7 / 24</u>	Title: <u>Public Works Lead</u> Phone #: <u>(541) 701-8880</u>	Operator Certification #: <u>900039</u>
---	---	---

Ranney (Raw) Stations Log

For the Month of:

January

Collector #1										Collector #2										Flow Meters											
Total Pump Hours					Daily Hours					Total Pump Hrs.					Daily Hrs.					Collector #2					Collector #1					Daily Coll. Flows	
Date	Time	Initials	#1	#2	#3	#1	#2	#3	#1	#2	#3	#1	#2	#3	#1	#2	#3	GPM	Total	Daily	GPM	Total	Daily								
Last Reading ==>						x	x	x																							
1	7:54	N.A.	0	0	0							1	0					564	190868	954	3273	162215	1375	2329							
2	7:10	JP	1	0	0	1	0	0				3	0					5611	91281	913	3250	163642	1427	2346							
3	7:10	JP	2	0	0	1	0	0				4	0					5420	92795	1614	3200	164999	1357	2371							
4	7:10	JP	2	0	0	0	0	0				3	0					5400	93779	984	3320	166464	1465	2449							
5	7:10	JP	3	0	0	1	0	0				5	0					5550	94857	1028	3230	167942	1428	2556							
6	8:23	JP	4	0	0	1	0	0				4	0					5430	95914	1057	3356	169460	1518	2575							
7	8:10	JP	5	0	0	1	0	0				4	0					5530	96882	968	3270	170925	1465	2433							
8	7:10	JP	5	0	0	0	0	0				3	0					5330	97838	956	3256	172309	1484	2440							
9	7:10	JP	6	0	0	1	0	0				4	0					5320	98831	993	3350	173745	1436	2429							
10	7:10	JP	7	0	0	1	0	0				4	0					5450	99860	1029	3320	175270	1525	2554							
11	7:19	N.A.	8	0	0	1	0	0				4	0					5389	100841	981	3392	176821	1551	2532							
12	7:19	JP	8	0	0	0	0	0				3	0					5493	101852	1611	3215	178275	1454	2465							
13	7:55	JP	9	0	0	1	0	0				4	0					5346	102827	975	3273	179544	1529	2444							
14	7:55	JP	10	0	0	1	0	0				4	0					5420	103802	979	3310	180911	1367	2346							
15	7:55	JP	11	0	0	1	0	0				4	0					5330	104794	990	3297	182417	1506	2496							
16	7:52	N.A.	11	0	0	0	0	0				3	0					5389	105768	972	3321	183782	1365	2337							
17	7:10	JP	12	0	0	1	0	0				4	0					5389	106917	1149	3329	185456	1674	2823							
18	7:00	JP	13	0	0	1	0	0				4	0					5481	107712	795	3221	186657	1203	1998							
19	7:00	JP	13	0	0	0	0	0				3	0					5642	108808	1095	3373	188224	1565	2660							
20	7:38	JP	14	0	0	1	0	0				4	0					5694	109865	1057	3382	189784	1560	2617							
21	7:46	JP	15	0	0	1	0	0				5	0					5778	110895	1030	3389	191470	1686	2716							
22	7:46	JP	16	0	0	1	0	0				4	0					5704	111913	1018	3244	193104	1634	2652							
23	7:16	JP	17	0	0	1	0	0				4	0					5702	113080	1167	3256	194744	1640	2807							
24	7:10	JP	18	0	0	1	0	0				4	0					5705	114092	1012	3230	196487	1743	2755							
25	7:10	JP	18	0	0	0	0	0				4	0					5694	115196	1104	3250	198057	1570	2679							
26	7:19	N.A.	19	0	0	1	0	0				4	0					5819	116228	1032	3217	199566	1509	2541							
27	7:34	N.A.	20	0	0	1	0	0				4	0					5721	117277	1049	3257	201221	1655	2704							
28	7:33	N.A.	21	0	0	1	0	0				4	0					5798	118363	1086	3281	202853	1637	2718							
29	7:10	JP	22	0	0	1	0	0				7	0					5670	120138	1775	3255	204181	1328	3043							
30	7:10	JP	22	0	0	0	0	0				3	0					5430	121245	1107	3210	20568	1387	2494							
31	7:10	JP	23	0	0	1	0	0				4	0					5620	122298	1053	3320	206919	1387	2404							