

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems

System Name: Canby Regency

PWS ID# 4 1 00163

March / 2023

Treatment Room

Month/Year: /

Minimum Residual: 0.3 Mg/L



	Time	Source(s) in use	Free chlorine Residual at treatment room (mg/L)	Notes
1	10:28	Spring	0.5	
2	14:21	Spring	0.6	
3	09:00	Spring	0.4	
4	09:00	Spring	0.6	
5	13:30	Spring	0.6	
6	08:15	Spring	0.6	
7	08:00	Spring	0.6	
8	09:54	Spring	0.8	
9	13:17	Spring	0.8	
10	09:45	Spring	0.8	
11	09:00	Spring	0.8	
12	14:25	Spring	0.8	
13	10:00	Spring	0.8	
14	09:25	Spring	0.7	
15	08:30	Spring	0.8	
16	12:24	Spring	0.8	
17	08:00	Spring	0.8	
18	08:00	Spring	0.8	
19	14:00	Spring	0.8	
20	09:00	Spring	0.8	
21	17:00	Spring	0.8	
22	07:27	Spring	0.9	
23	12:36	Spring	0.9	
24	15:00	Spring	0.8	
25	10:00	Spring	0.8	
26	17:00	Spring	0.8	
27	17:00	Spring	0.6	
28	14:27	Spring	0.8	
29	10:40	Spring	0.8	
30	10:01	Spring	0.8	
31	17:00	Spring	0.8	

Were the chloring residuals at the treatment room ever less than the required minimum residual of .3mg/L? ☐ Yes ☒ No
 If yes, what was the time period until the required level was restored? _____ hours – If > 4 hours, Drinking Water Program to be notified
 by end of next business day.

GWS Serving 3,300 or Fewer

If yes, did you monitor chlorine residuals at treatment room every four hours until the residual returned to .3mg/L as required?

☐ Yes ☐ No

Attach those results and submit them with this form.

Printed Name: Mary L Howell Title: DRC
 Signature: *Mary L. Howell* Phone #: (503) 255-1619
 Date: 04/11/23

Operator Certification #
 OR D-142
 Small Ground Water System