

**State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems**

System Name City of Columbia City PWS ID# 41 00203  
 Month/Year Jun 2022 Entry Point: EP-C Required Minimum Residual 0.2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	4:30pm	P.W. Well # 2	.68	
2			.73	
3			.78	
4			.73	
5			.72	
6			.69	
7			.70	
8			.73	
9			.70	
10			.69	
11			.65	
12			.70	
13			.71	
14			.71	
15			.68	
16			.70	
17			.71	
18			.72	
19			.72	
20			.73	
21			.71	
22			.71	
23			.68	
24			.66	
25			.72	
26			.76	
27			.72	
28			.80	
29			.73	
30			.80	
31			.71	

Was the chlorine residual ever less than the required minimum residual of 0.2 mg/L?  Yes  No  
 If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ Hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p><b>GWS Serving 3,300 or Fewer</b></p> <p>If yes, did you monitor every four hours until the residual returned to ___ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p><b>GWS Serving More Than 3,300</b></p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>	<p>Date continuous monitoring equipment failed: _____/_____/_____</p> <p>Date it was returned to service: _____/_____/_____</p>
--	--	---

Printed Name: Micah Rogers Title: P.W. Superintendent Operator Certification #: D-7227  
 Signature: Micah Rogers Phone #: (503) 366-0454 OR  
 Date: 2/7/22 Small Groundwater System