

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name City of Columbia City PWS ID# 41 00203
 Month/Year Sept 12 2022 Entry Point: EP-C Required Minimum Residual 0.2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	4:30 pm	P.W. Well #2	.68	
2		St. Helens	.65	
3		EP-A	.67	
4			.68	
5			.68	
6			.67	
7			.68	
8			.64	
9			.67	
10			.65	
11			.64	
12			.65	
13			.64	
14			.60	
15			.67	
16			.71	
17			.68	
18			.70	
19			.73	
20			.68	
21			.75	
22			.74	
23			.70	
24			.75	
25			.68	
26			.69	
27			.65	
28			.68	
29			.70	
30			.70	
31				

Was the chlorine residual ever less than the required minimum residual of 0.2 mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ Hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to ___ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>	<p>Date continuous monitoring equipment failed: _____/_____/_____</p> <p>Date it was returned to service: _____/_____/_____</p>
--	--	---

Printed Name: Micah Rogers Title: P.W. Superintendent Operator Certification #: D-7227
 Signature: Micah Rogers Phone #: (503) 366-0454
 Date: 10/10/22

OR
 Small Groundwater System