

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name City of Columbia City
Month/Year April 12023 Entry Point: EP-C

PWS ID# 4100203
Required Minimum Residual 0.2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	4:30pm	P.W. Well #2	.67	
2			.60	
3			.70	
4			.63	
5			.68	
6			.82	
7			.80	
8			.65	
9			.71	
10			.67	
11			.74	
12			.70	
13			.67	
14			.67	
15			.68	
16			.67	
17			.65	
18			.69	
19			.75	
20			.71	
21			.72	
22			.68	
23			.67	
24			.74	
25			.66	
26			.71	
27			.69	
28			.83	
29			.75	
30			.75	
31				

Was the chlorine residual ever less than the required minimum residual of 0.2 mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach those results and submit them with this form.</i></p>	<p align="center">GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach grab sample results and submit them with this form.</i></p>	<p>Date continuous monitoring equipment failed: / /</p> <p>Date it was returned to service: / /</p>
---	--	---

Printed Name: Micah Rogers Title: P.W. Superintendent Operator Certification #: D-7227
 Signature: Micah Rogers Phone #: (503) 366-0454 OR
 Date: 5/14/23 Small Groundwater System

Return by 10th of following month by either email dwp.dmce@state.or.us; fax 971-673-0694; or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.