

**State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems**

System Name City of Columbia City PWS ID# 4100203  
 Month/Year Sept 1 2023 Entry Point: EP-C Required Minimum Residual 0.2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	4:30 pm	P.W. Well #2	.71	
2			.68	
3			.67	
4			.69	
5			.65	
6			.75	
7			.68	
8			.70	
9			.68	
10			.70	
11			.68	
12			.66	
13			.67	
14			.64	
15			.64	
16			.67	
17			.60	
18			.64	
19			.86	
20			.63	
21			.75	
22			.60	
23			.70	
24			.75	
25			.70	
26			.84	
27			.64	
28			.59	
29			.58	
30			.64	

Was the chlorine residual ever less than the required minimum residual of 0.2 mg/L?  Yes  No  
 If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p><b>GWS Serving 3,300 or Fewer</b></p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach those results and submit them with this form.</i></p>	<p align="center"><b>GWS Serving More Than 3,300</b></p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach grab sample results and submit them with this form.</i></p>	<p>Date continuous monitoring equipment failed: / /</p> <p>Date it was returned to service: / /</p>
---	--	---

Printed Name: Micah Rogers Title: P.W. Superintendent Operator Certification #: D-7227  
 Signature: [Signature] Phone #: (503) 366-0454 OR  
 Date: 10 16 23 Small Groundwater System

Return by 10<sup>th</sup> of following month by either email [dwp.dmce@state.or.us](mailto:dwp.dmce@state.or.us); fax 971-673-0694; or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.