

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name City of Columbia City
Month/Year Aug 12025 Entry Point: EP-C

PWS ID# 4100203
Required Minimum Residual 0.2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	4:30pm	P.W. Well # 2	.61	
2			.67	
3		City of St. Helens	.61	
4		EP-A	.70	
5			.69	
6			.58	
7			.68	
8			.81	
9			.72	
10			.81	
11			.63	
12			.68	
13			.61	
14			.81	
15			.73	
16			.78	
17			.79	
18			.75	
19			.63	
20			.82	
21			.70	
22			.78	
23			.74	
24			.78	
25			.68	
26			.67	
27			.67	
28			.71	
29			.78	
30			.65	
31			.64	

Was the chlorine residual ever less than the required minimum residual of 0.2 mg/L? ☐ Yes ☒ No
If yes, what was the longest time period until the required level was restored? _____ hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer

If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? ☐ Yes ☐ No
Attach those results and submit them with this form.

GWS Serving More Than 3,300

Did continuous monitoring equipment fail at any time this reporting month? ☐ Yes ☐ No
If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? ☐ Yes ☐ No
Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed: _____ / _____ / _____
Date it was returned to service: _____ / _____ / _____

Printed Name: Micah Rogers
Signature: Micah Rogers
Date: 9/10/25

Title: P.W. Superintendent
Phone #: (503) 866-0454

Operator Certification #: D-7227
OR
Small Groundwater System ☐

Return by 10th of following month by either email dwp.dmce@state.or.us; fax 971-673-0694; or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.

August 22, 2019