

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name City of Columbia City PWS ID# 4100203
 Month/Year Entry Point: Required Minimum Residual 0.2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	4:30pm	P.W. Well #2	.65	
2			.72	
3			.72	
4			.56	
5			.72	
6			.78	
7			.67	
8			.66	
9			.74	
10			.72	
11			.70	
12			.64	
13			.84	
14			.66	
15			.70	
16			.74	
17			.74	
18			.64	
19			.63	
20			.68	
21			.67	
22			.73	
23			.78	
24			.77	
25			.75	
26			.76	
27			.76	
28			.78	
29				
30				
31				

Was the chlorine residual ever less than the required minimum residual of 0.2 mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach those results and submit them with this form.</i></p>	<p align="center">GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach grab sample results and submit them with this form.</i></p>
<p>Date continuous monitoring equipment failed: / /</p> <p>Date it was returned to service: / /</p>	

Printed Name: Michah Rogers Title: P.W. Superintendent Operator Certification #: 0-7227
 Signature: Michah Rogers Phone #: (503) 366-0134 OR
 Date: 3/10/26 Small Groundwater System

Return by 10th of following month by either email dwp.dmce@state.or.us; fax 971-673-0694; or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.