

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name City of Columbia City PWS ID# 4100293
 Month/Year March 2026 Entry Point: EP-C Required Minimum Residual 0.2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	4:30pm	P.W. Well #2	.76	
2			.75	
3			.68	
4			.60	
5			.78	
6			.76	
7			.71	
8			.80	
9			.66	
10			.67	
11			.70	
12			.74	
13			.64	
14			.76	
15			.64	
16			.79	
17			.75	
18			.74	
19			.74	
20			.72	
21			.68	
22			.68	
23			.68	
24			.67	
25			.74	
26			.83	
27			.76	
28			.78	
29			.79	
30			.79	
31			.76	

Was the chlorine residual ever less than the required minimum residual of 0.2 mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>	<p>Date continuous monitoring equipment failed: / /</p> <p>Date it was returned to service: / /</p>
--	--	---

Printed Name: Micah Rogers Title: P.W. Superintendent Operator Certification #: 0-7227
 Signature: Micah Rogers Phone #: (503) 366-0454 OR
 Date: 4/10/2026 Small Groundwater System

Return by 10th of following month by either email dwp.dmce@state.or.us; fax 971-673-0694; or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.