

Monthly Disinfection Report for Ground Water Systems

RECEIVED

System Name **Laurel Acres Water**

JUL 08 2022 PWS ID# 41 00217

Month/Year June 2022 Entry Point: WTP #1

Health & Human Services
Environmental Health

Required Minimum Residual mg/L 0.3

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1			.34	
2			.35	
3			.35	
4			.36	
5			.37	
6			.34	
7			.39	
8			.38	
9			.38	
10			.38	
11			.37	
12			.37	
13			.37	
14			.35	
15			.34	
16			.33	
17			.32	
18			.32	
19			.33	
20			.33	
21			.32	
22			.32	
23			.33	
24			.33	
25			.33	
26			.34	
27			.35	
28			.35	
29			.35	
30			.35	
31			.36	

Was the chlorine residual ever less than the required minimum residual of 0.3 mg/L? ☐ Yes ☒ No
 If yes, what was the longest time period until the required level was restored? _____ hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer

If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? ☐ Yes ☐ No

Attach those results and submit them with this form.

GWS Serving More Than 3,300

Did continuous monitoring equipment fail at any time this reporting month? ☐ Yes ☐ No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? ☐ Yes ☐ No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed: / /

Date it was returned to service: / /

Printed Name: Leo Jones

Signature: Leo Jones

Date: 7/18/22

Title: well operator

Phone #: (503) 9694415

Operator Certification #:

OR

Small Groundwater System ☒