

Monthly Disinfection Report for Ground Water Systems

System Name **Laurel Acres Water**

PWS ID# **41 00217**

Month/Year **2 123** Entry Point: **WTP-A**

Required Minimum Residual **mg/L 0.3**

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1				
2			0.38	
3			0.34	
4			0.34	
5			0.35	
6			0.35	
7			0.36	
8			0.37	
9			0.37	
10			0.36	
11			0.37	
12			0.36	
13			0.36	
14			0.35	
15			0.34	
16			0.35	
17			0.35	
18			0.34	
19			0.34	
20			0.35	
21			0.35	
22			0.36	
23			0.35	
24			0.36	
25			0.36	
26			0.37	
27			0.37	
28			0.38	
29			0.38	
30				
31				

Was the chlorine residual ever less than the required minimum residual of 0.3 mg/L? ☐ Yes ☒ No

If yes, what was the longest time period until the required level was restored?
notified by end of next business day.

hours - If > 4 hours, Drinking Water Program to be

GWS Serving 3,300 or Fewer

If yes, did you monitor every four hours until the residual returned to mg/L as required? ☐ Yes ☐ No

Attach those results and submit them with this form.

GWS Serving More Than 3,300

Did continuous monitoring equipment fail at any time this reporting month? ☐ Yes ☒ No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? ☐ Yes ☐ No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed:

Date it was returned to service:

Printed Name: **Leo Jones**

Signature: *Leo Jones*

Date: **3 11 123**

Title: **Operator**

Phone #: **(503) 964-4415**

Operator Certification #:

OR

Small Groundwater System ☒