## State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System Name Riverstone MHP PWS ID# 4 1 00240						
Month/	Year _0	1/2025 Entry Po	int: Pump Hous	Pump House Required Minimum Residual .20 mg/L		
Date	Time	Source(s) i	n use	Lowest free chlorine residual at entry point to distribution system (mg/L	)	Notes
1	9:30	Well 1 and 2		.34		
2	9:30	11		.36		
3	9:30			.36		
4	9:30	"		.35		
5	9:30	11		.35		
6	9:30	11		.35		
7	9:30	"		.36		
8	9:30	J.		.36		
9	9:30	III		.36		
10	9:30			.35		11(5-21)
11	9:30	11		.38		
12	9:30	II .		.38		
13	9:30	n .		.36		
14	9:30	11		.36		
15	9:30	11		.37		
16	9:30	Ħ		.38		
17	9:30			.38		
18	9:30	II.		.37		
19	9:30	II .		.37		
20	9:30	H.		.37		
21	9:30	1		.37		American Control of the Control of t
22	9:30	II.		.36		
23	9:30	u u		.36		
24	9:30	ii.		.37		
25	9:30	11		.37		
26	9:30	"		.37		
27	9:30	"		.36		50 - 50 - 100 - AND 00 - 160
28	9:30	"		.37		
29	9:30	11		.38		
30	9:30	"		.37		
31 9.50   .54						
If yes,	what was th	e longest time period unt	12 New 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	residual of .20 mg/L? \( \subseteq \) was restored? hours		rinking Water Program to be
notified by end of next business day.  GWS Serving 3,300 or Fewer  GWS Serving More Than 3,300						
GWS Serving 3,300 or Fewer  If yes, did you monitor every four hours until the residual returned to mg/L as required? Yes No  Attach those results and submit them with this form.			Did continuous monitoring equipment fail at any time this reporting month?  Yes No			Date continuous monitoring equipment failed:
			If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required?   Yes No			/ / Date it was returned to service:
Attach grab sample results and submit them with this form.						
Printed Name: Misty Dean			Title: Manager/Operator		Operator Certification #:	
Signatu	re: N	Posty Dec			OR	
Date: 0			1 Holl	A TO A STATE OF THE	Small G	roundwater System