## State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System	Name	Riverstone MHP		PWS ID# 4 1 00240		
Month/	Year _04	/2025 Entry Poi	nt: Pump Hou	louse Required Minimum Residual .20 mg/L		
Date	Time	Source(s) ir	n use	Lowest free chlorine residual at entry point to distribution system (mg/L	)	Notes
1	9:30	Well 1 and 2		.33		
2	9:30	7		.31		
3	9:30	"		.28		
4	9:30	"		.22		
5	9:30	U		.32		
6	9:30	"		.29		
7	9:30	H		.26		
8	9:30	n	05	.26		- Company and a second
9	9:30	0		.26		
10	9:30	11		.26		
11	9:30	11		.21		
12	9:30	U U		.21		
13	9:30	W.		.28		A
14	9:30	11		.28		
15	9:30	II.		.31		
16	9:30	JI.		.35		
17	9:30	11		.31		
18	9:30	п		.29		
19	9:30			.25		
20	9:30			.23		
21	9:30	11		.23		
22	9:30	U		.35		
23	9:30	11		.33		
24	9:30	11		.31		
25	9:30			.33		
26	9:30	11		.29		
27	9:30	in.		.29		
28	9:30			.35		
29	9:30	11		.29		was kind of the second of the second
30	9:30	и		.25		
31	9:30	T .				
Was the chlorine residual ever less than the required minimum residual of .20 mg/L? Yes No  If yes, what was the longest time period until the required level was restored? hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.						
GWS Serving 3,300 or Fewer GWS Serving More Than 3,300						
If yes, did you monitor every four hours until the residual returned to mg/L as required?			Did continuous monitoring equipment fail at a reporting month? ☐ Yes ☐ No		any ume uns	Date continuous monitoring equipment failed:
			M 5000			l l
Attach those results and submit them with			If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as			Date it was returned to
this form.			required? Yes No			service:
			Attach grab sample results and submit them with		with this form.	1 1
Printed	Name: Misty	Dean	Title: Manager/Operator		Operator Certification #:	
Production (P)	No					
Signatur	e: ////	Shy Coa.	Phone #: (541) 942-4147		OR	
Date: 04 / 1 / 25 Small Groundwater System 🖂						