## State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System Name Riverstone MHP PWS ID# 4 1 00240							
Month/Year _06/2025 Entry Point: Pump House Required Minimum Residual .20 mg/L							
Date	Time	Source(s) in	use	Lowest free chlorine residual at entry point to distribution system (mg/L)		Notes	
1	9:30	Well 1 and 2		31			
2	9:30	tf.		30			
3	9:30	11		.30			
4	9:30	11		.35			
5	9:30	11		.37			
6	9:30	H		.31			
7	9:30	TI T		.29			
8	9:30	Н		.28			
9	9:30	U		.29			
10	9:30	11		.30			
11	9:30	19		.25			
12	9:30	11		.28			
13	9:30	11		.26			
14	9:30	11		.29	_		
15	9:30	H .		.26			
16	9:30	P		.31			
17	9:30	11		.33			
18	9:30	11		.31			
19	9:30			.29			
20	9:30	1		.25			
21	9:30	м		.23			
22	9:30			.23			
23	9:30	M.		.25			
24	9:30	li .		.23			
25	9:30	11		.31			
26	9:30	n.		.29			
27	9:30	"		.31			
28	9:30	<u> </u>		.38			
29	9:30	11		.30			
30	9:30	11		.29			
31	9:30	11					
Was the chlorine residual ever less than the required minimum residual of .20 mg/L? Yes No  If yes, what was the longest time period until the required level was restored? hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.							
GWS Serving 3,300 or Fewer GWS Serving More Than 3,300							
If yes, until th as req Attach	did you mon e residual re uired?	itor every four hours	Did continuous monitoring equipment fail at any time this reporting month? ☐ Yes ☒ No  If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service a required? ☐ Yes ☐ No			Date continuous monitoring equipment failed:  / / Date it was returned to service:	
this for	m.		Attach grab sample results and submit them with this form.		1 1		
Printed Name: Misty Dean Title: Manager/Operator Operator Certification #:						r Certification #:	
Signatu	Signature:					OR	
					Small Groundwater System		
Date: 06 / 1/25						odilowater Oystern M	