State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System Name Riverstone MHP				PWS ID# 4 1 00240			
Month/	Year _07	7/2025 Entry I	Point: Pump Ho	p House Required Minimum Residual .20 mg/L			
Date	Time	Source(s	s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes	
1	9:30	Well 1 and 2		.24			
2	9:30	11		.25			
3	9:30	11		.22			
4	9:30	11,		.26			
5	9:30	н		.28			
6	9:30	н		.29			
7	9:30	11		.31			
8	9:30	н		.29			
9	9:30	"		.23			
10	9:30	11		.27			
11	9:30	П		.26			
12	9:30	11		.29			
13	9:30	"		.28			
14	9:30	11		.32	-		
15	9:30	"		.31			
16	9:30	п		.30			
17	9:30	H		.31			
18	9:30	н					
19	9:30			.31			
-		11		.30			
20	9:30	В		.31			
21	9:30	н		.31			
22	9:30	н		.39			
23	9:30	н		.39			
24	9:30	"		.31			
25	9:30	"		.35			
26	9:30			.28			
27	9:30	"		.26			
28	9:30			.26			
29	9:30	"		.24			
30	9:30	"		.26			
31	9:30	11	STATE OF THE STATE	.25			
Was the chlorine residual ever less than the required minimum residual of .20 mg/L? Yes No If yes, what was the longest time period until the required level was restored? hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.							
GWS Serving 3,300 or Fewer GWS Serving More Than 3,300							
If yes, did you monitor every four hours until the residual returned to mg/L as required?			reporting mont	Did continuous monitoring equipment fail at any reporting month? Yes No If yes, were grab samples collected every four here.		Date continuous monitoring equipment failed:	
Attach those results and submit them with this form.			continuous mo required?	initoring equipment was returned Yes No imple results and submit them	ed to service as	Date it was returned to service:	
Printed I	Name: Misty			Title: Manager/Operator		Operator Certification #:	
Signatur	re: ///	200 10	Pho Pho	one #: (541) 942-4147 OR			
	7/1/25	1		,	Small G	roundwater System 🖂	