

State of Oregon Drinking Water Program  
**Monthly Disinfection Report for Ground Water Systems**

System Name	Riverstone MHP	PWS ID#	4 1 00240
Month/Year	_02/2026	Entry Point:	Pump House
		Required Minimum Residual	.20 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	9:30	Well 1 and 2	.43	
2	9:30	"	.43	
3	9:30	"	.39	
4	9:30	"	.39	
5	9:30	"	.36	
6	9:30	"	.38	
7	9:30	"	.35	
8	9:30	"	.38	
9	9:30	"	.36	
10	9:30	"	.35	
11	9:30	"	.36	
12	9:30	"	.35	
13	9:30	"	.35	
14	9:30	"	.37	
15	9:30	"	.34	
16	9:30	"	.30	
17	9:30	"	.31	
18	9:30	"	.29	
19	9:30	"	.31	
20	9:30	"	.33	
21	9:30	"	.32	
22	9:30	"	.33	
23	9:30	"	.32	
24	9:30	"	.31	
25	9:30	"	.29	
26	9:30	"	.31	
27	9:30	"	.30	
28	9:30	"	.31	
29	9:30	"		
30	9:30	"		
31	9:30	"		

Was the chlorine residual ever less than the required minimum residual of .20 mg/L?  Yes  No  
 If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p><b>GWS Serving 3,300 or Fewer</b></p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach those results and submit them with this form.</i></p>	<p><b>GWS Serving More Than 3,300</b></p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach grab sample results and submit them with this form.</i></p>	<p>Date continuous monitoring equipment failed:                  / /</p> <p>Date it was returned to service:                  / /</p>
---	---	---

Printed Name: Misty Dean	Title: Manager/Operator	Operator Certification #:
Signature:	Phone #: (541) 942-4147	OR
Date: 02/11/26		Small Groundwater System <input checked="" type="checkbox"/>