

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems

System Name Hopewell Water Company

PWS ID# 41 00251

Month/Year 04 / 2023 Entry Point: A

Required Minimum Residual 0.8 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes	
1	5:11	FENTON'S GARAGE	0.8		
2	5:29		0.8		
3	5:17		1.2		
4	3:42		1.2		
5	3:27		1.1		
6	3:50		1.0		
7	3:20		1.0		
8	5:14		0.9		
9	5:21		0.9		
10	5:35		0.8		
11	3:25		0.8		
12	3:15		1.2		
13	3:32		1.2		
14	3:37		1.1		
15	5:08		1.1		
16	5:10		1.0		
17	5:27		1.0		
18	3:02		0.9		
19	3:41		0.8		
20	3:10		0.8		
21	3:12		1.2		
22	5:12		1.2		
23	5:36		1.1		
24	5:42		1.1		
25	3:21		1.0		
26	3:40		0.9		
27	3:39		0.9		
28	3:19		0.8		
29	5:16		0.8		
30	5:35		1.2		
31					

Was the chlorine residual ever less than the required minimum residual of 0.8 mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>
<p>Date continuous monitoring equipment failed: _____ / _____ / _____</p> <p>Date it was returned to service: _____ / _____ / _____</p>	

Printed Name: BRETT ALDRICH Title: WATER MASTER Operator Certification #: _____
 Signature: Phone #: (503) 871-0457 OR _____
 Date: 05 / 02 / 2023 Small Groundwater System