

State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems

System Name Hopewell Water Company

PWS ID# 41 00251

Month/Year 02/2024 Entry Point: A

Required Minimum Residual 0.8 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	3:40	FENTON'S GARAGE	0.8	
2	3:52		0.8	
3	5:08		1.2	
4	5:14		1.1	
5	5:27		1.1	
6	3:19		1.0	
7	3:20		1.0	
8	3:27		0.9	
9	3:42		0.9	
10	5:10		0.8	
11	5:21		0.8	
12	5:17		1.2	
13	3:32		1.2	
14	3:37		1.1	
15	3:42		1.1	
16	3:50		1.0	
17	5:42		1.0	
18	5:11		0.9	
19	5:29		0.8	
20	3:39		0.8	
21	3:22		1.2	
22	3:21		1.1	
23	3:39		1.1	
24	5:36		1.0	
25	5:50		1.0	
26	5:18		0.9	
27	3:16		0.9	
28	3:25		0.8	
29	3:12		0.8	
30	—		—	
31	—		—	

Was the chlorine residual ever less than the required minimum residual of 0.8 mg/L?  Yes  No  
 If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ hours — If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p><b>GWS Serving 3,300 or Fewer</b></p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p><b>GWS Serving More Than 3,300</b></p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>	<p>Date continuous monitoring equipment failed: / /</p> <p>Date it was returned to service: / /</p>
--	--	---

Printed Name: Brett Aldrich Title: Water Master Operator Certification #: \_\_\_\_\_  
 Signature: Brett Aldrich Phone #: (503) 871-0457 OR  
 Date: 03/02/2024 Small Groundwater System

Return by 10<sup>th</sup> of following month by either email [dwp.dmce@state.or.us](mailto:dwp.dmce@state.or.us); fax 971-673-0694; or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.